

Portland Fire Department Monthly School Inspection

Name: <u>GRACE BAPTIST</u>	Address: <u>476 SUMMIT ST</u>
Principal: <u>MR ST EURS</u>	Emergency contact #: <u>GARY OUELLETTE</u>

Date Inspected: <u>1-27-09</u>	Inspector: <u>D. LORD</u>
Time in: <u>1205</u>	Time out: <u>1220</u>

Fire Drills Conducted Yes ☒ No ☐ Date of last drill: _____

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail	Notes:
<u>X</u>		
<u>X</u>		

Fire Alarm System

Panel clear, accessible, operational

<u>X</u>		
----------	--	--

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<u>X</u>		
<u>X</u>		

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<u>X</u>		
<u>X</u>		

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<u>X</u>		
<u>X</u>		
<u>X</u>		

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date


<u>S</u>		
<u>S</u>		
<u>S</u>		

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<u>X</u>		
<u>X</u>		
<u>X</u>		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>GRACE BAPTIST</u>	Address: <u>476 SUMMIT ST</u>
Principal: <u>DWAYNE STONE</u>	Emergency contact #: <u>GARY OUELLETTE</u>

Date inspected: <u>9-16-09</u>	Inspector: <u>LT D. LORD</u>
Time in:	Time out:

39 STUDENTS

Fire Drills Conducted Yes ☐ No ☐ Date of last drill: NOT YET

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

1 EXIT, DOOR LOCKED
3 EXIT SIGNS IN GYM

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

SCHEDULED

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date


<u>N/A</u>	<input type="checkbox"/>
<u>N/A</u>	<input type="checkbox"/>
<u>N/A</u>	<input type="checkbox"/>
<u>N/A</u>	<input type="checkbox"/>

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>MOORE MIDDLE</u>	Address: <u>171 AUBURN ST</u>
Principal: <u>LEE CROCKER</u>	Emergency contact #: <u>MIKE MOWATT</u>

Date inspected: <u>9-14-09</u>	Inspector: <u>LT D. LORD</u>
Time in: <u>1310</u>	Time out: <u>1325</u>

534 STUDENTS

Fire Drills Conducted Yes ☐ No ☒ Date of last drill: NOT YET

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

WATCH ANNUNCIATOR

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>


House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:

WED:
10AM



Portland Fire Department Monthly School Inspection

Name: <u>LYSETH ELEM</u>	Address: <u>175 AUBURN ST</u>
Principal:	Emergency contact #: <u>MIKE GILLESPIE</u>

Date inspected: <u>9-14-09</u>	Inspector: <u>LY D. LORD</u>
Time in: <u>1325</u>	Time out:

489 STUDENTS

Fire Drills Conducted Yes ☒ No ☐ Date of last drill: (2) 9-10-09

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass / Fail

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

JANITORS ROOM

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>


House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:

3RD EMER EXIT HDW BROKEN



Portland Fire Department Monthly School Inspection

~~432-2135~~
~~324-5650~~

Name: <u>PATHS</u>	Address: <u>196 ALLEN AVE</u>
Principal: <u>DANA ALLEN</u>	Emergency contact #: <u>STEVE THOMES</u>

Date Inspected: <u>9-14-09</u>	Inspector: <u>LT D. LORD</u>
Time in: <u>1010</u>	Time out: <u>1048</u>

Fire Drills Conducted Yes ☐ No ☒ Date of last drill: NOT YET

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass ☒ Fail ☐

Notes:

Fire Alarm System

Panel clear, accessible, operational

☒ ☐

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

☒ ☐
☒ ☐

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

☒ ☐
☒ ☐

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

☒ ☐
☒ ☐
☒ ☐

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

☒ ☐
☒ ☐
☒ ☐
☒ ☐

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

☒ ☐
☒ ☐
☒ ☐

Additional Safety Concerns:

ANNUAL SPRINKLER TEST ?
JUNK IN FRT OF ELEC. PANELS
CO₂ + ARGON TANKS UNSECURED