

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

DORLER RONALD J TRUSTEE

Located at

7 MORNINGSTAR LN

PERMIT ID: 2014-02237

ISSUE DATE: 11/24/2014

CBL: 385 C011001

has permission to **Build new 2 story, 2.5 bathroom, 3 bedroom with attached garage single family Home - 32' x 26'**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Use Group: R-3

Type: 5B

Single Family

ENTIRE

MUBEC 2009

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Setbacks and Footings Prior to Pouring
Foundation/Backfill
Electrical Service
Close-in Plumbing/Framing
Electrical - Residential
Certificate of Occupancy/Final
Electrical Service
Final - DRC

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-02237	Date Applied For: 09/22/2014	CBL: 385 C011001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single Family Home	Proposed Project Description: Build new 2 story, 2.5 bathroom, 3 bedroom with attached garage single family Home - 32' x 26'			
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 11/24/2014				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.				
2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
3) Before the Certificate of Occupancy is issued, we will need a copy of the recorded deed for the specific lot.				
Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson Approval Date: 10/14/2014				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Tempered safety glazing is required at all hazardous locations per IRC 2009 Sec. R308.4 and IBC 2009 Sec. 2406.4				
2) The stair construction shall comply with IRC Sec. R311 which includes, but is not limited to, a maximum riser height of 7-3/4" and a minimum net tread of 10", and nosings not less than 3/4" but not more than 1-1/4" where solid risers are required.				
3) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all bedrooms, protecting the bedrooms, and on every level.				
The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.				
4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
5) When over 30" above a floor or grade, guardrail openings shall be less than 4", stairail openings shall be less than 4-3/8", and at the open side of a stair, less than 6" is allowed at the triangle of the tread/riser at the bottom rail.				
6) Energy Code compliance shall be confirmed via a ResCheck or ComCheck, http://www.energycodes.gov/software.stm#tabs-2 certificate or alternate program standard for thermal envelope and MEP systems. This documentation is required prior to associated work for these items.				
7) Egress size windows are required (1) in each bedroom per IRC Sec. R310				
8) The design load spec sheets for any engineered beam(s) / Trusses must be submitted to this office.				
9) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.				
10) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messenger Approval Date: 10/09/2014				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Shall meet the requirements of 2009 NFPA 1 Fire Code.				
2) All construction shall comply with City Code Chapter 10.				

3) Shall meet the requirements of NFPA 13D.

Dept: DRC

Status: Approved w/Conditions

Reviewer: Philip DiPierro

Approval Date: 11/24/2014

Note:

Ok to Issue:

Conditions:

- 1) Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintained daily.
- 2) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.
- 3) All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy.
- 4) A sewer permit is required for your project. Please contact Carol Merritt at 874-8300, ext. 8822. The Wastewater and Drainage section of Public Services must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.
- 5) A street opening permit(s) is required for your site. Please contact Carol Merritt at 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)
- 6) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.
- 7) The deed to the property must be amended to comply with the original subdivision condition of approval that requires the approved plot plan to be recorded at the Registry of Deeds. A note on the plot plan must include repeating recording Plan Tree Save/Protection Areas Note 1 regarding the Tree Save/Protection Areas. This condition must be met prior to the issuance of any Certificate of Occupancy.
- 8) The Planning Department Development Review Coordinator must receive a copy of the proposed deed (based on the sample deed that was approved by the City's Legal Department during the project subdivision review and approval), prior to the issuance of either a temporary or permanent Certificate of Occupancy. A copy of the recorded deed must be submitted to the Development Review Coordinator immediately after recording.
- 9) The limits of allowable clearing shall be clearly marked with flagging or temporary fencing. Absolutely no clearing is to take place within, or encroach into the "do not disturb/no cut" zone. All conditions listed in the approved subdivision plan, as they relate to this lot shall be followed.
- 10) The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent monumentation/pins identifying property corners.
- 11) This site must comply with the Landscape Preservation Standards outlined in the Land Use Ordinance, section 14-526(b)2a, stating that a minimum of 30% of existing trees, ten (10) inches DBH or greater, within the required setback, must be preserved. Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily.
- 12) A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions i.e., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.
- 13) The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.
- 14) Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy.
- 15) The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.