DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

FY OF PORTLAN





This is to certify that

DORLER RONALD J TRUSTEE

Located at

33 MORNINGSTAR LN (lot 3)

PERMIT ID: 2017-00054 ISSUE DATE: 05/12/2017

385A A033001 CBL:

has permission to construct one story single family home - footprint is 38' x 64' which includes an attached garage (24' x 24').

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Jason Grant

/s/ Greg Gilbert

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning Single family

Building Inspections Use Group: Type: **Single Family** ENTIRE

MUBEC / 2009 IRC

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Site VISIT Final - DRC Foundation/Backfill Setbacks and Footings Prior to Pouring Close-in Plumbing/Framing Electrical - Residential Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

| City of Portland, Maine - Building or Use Permit | | Permit No: | Date Applied For: | CBL: | |
|--|------------|---------------------|-----------------------|----------------------------------|--|
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87 | 4-8716 | 2017-00054 | 01/13/2017 | 385A A033001 | |
| Proposed Use: Proposed Project Description: | | | | | |
| New Single-Family Home | construe | | | rint is 38' x 64' whicl | |
| Dept: Zoning Status: Approved w/Conditions Re | eviewer: | Ann Machado | Approval Da | te: 02/10/2017 | |
| Note: R-2 zone | | | | Ok to Issue: | |
| Conditions: | | | | | |
| 1) As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed structure, it may be required to be located by a surveyor. | | | | | |
| 2) With the issuance of this permit and the certificate of occupancy. This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. | | | | | |
| 3) This permit is being approved on the basis of plans submitted. A work. | ny deviati | ons shall require a | a separate approval b | efore starting that | |
| Dept: Building Inspecti Status: Approved w/Conditions Rev Note: | eviewer: | Greg Gilbert | Approval Da | te: 05/12/2017 Ok to Issue: ☑ | |
| Conditions: | | | | | |
| 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. | | | | | |
| 2) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code | | | | | |
| 3) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. | | | | | |
| 4) Connections and Fasteners to be installed per 2009 IBC Sec. 2304.9 and/or IRC Table R602.3(1) | | | | | |
| 5) All construction shall comply with City Code Chapter 10. A sprinkler system shall be installed. A separate no fee One- or Two-family Fire Sprinkler Permit is required. All smoke detectors and smoke alarms shall be photoelectric. Hardwired Carbon Monoxide alarms with battery backup are required on each floor. Sprinkler requirements The sprinkler system shall be installed in accordance with NFPA 13D. A compliance letter is required. All control valves shall be supervised in accordance with NFPA 13D. Pad locks shall only be installed on valves designed to be secured in the open position by pad lock. Application requires State Fire Marshal approval. | | | | | |
| 6) Ventilation of this space is required per ASRAE 62.2, 2007 editi For conditioned space- insulation shall comply with the IECC, 20 | | e State Energy Co | des). | | |
| 7) The garage shall be separated from the residence by not less than ½ inch gypsum board applied to the garage side, and structure (walls) supporting the separation. Garages beneath habitable rooms shall be separated from all habitable rooms above by not less than 5/8 inch Type X gypsum board or equivalent. R302.5.1 Opening protection. Openings from a private garage directly into a room used for sleeping purposes shall not be permitted. Other openings between the garage and residence shall be equipped with solid wood doors not less than 1 3/8 inches in thickness, solid or honeycomb core steel doors not less than 13/8 inches thick, or 20-minute fire-rated doors. | | | | | |
| Dept: Fire Status: Approved w/Conditions Re | eviewer: | Jason Grant | Approval Da | | |
| Note: Ok to Issue: 🗹 | | | | | |
| Conditions: | | | | | |

| 1) | City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. | | | |
|----|--|--|--|--|
| | Outside each separate sleeping area in the immediate vicinity of the sleeping areas On each level of the dwelling unit, including basements but excluding attics and crawl spaces. | | | |
| 2) | All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101, Chapter # 24 All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). | | | |
| 3) | City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be non- ionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations 1.Inside all sleeping rooms. 2.Outside each separate sleeping area, in the immediate vicinity of the sleeping areas | | | |
| | 3.On each level of the dwelling unit, including basements but excluding attics and crawl spaces. | | | |
| 4) | A separate City of Portland One and Two Family Sprinkler System Permit is required for all new sprinkler systems. This review does not include approval of system design or installation. Per 2009 NFPA 101 section 24.3.5.1 all new 1 and 2 family dwellings shall per protected throughout by an approved automatic sprinkler system. Sprinkler system installation shall comply with NFPA 13D or greater protection. | | | |
| D | ept: DRCStatus: Approved w/ConditionsReviewer: Rob Wiener/Phil DiPieApproval Date:03/08/2017 | | | |
| N | ote: Ok to Issue: 🗹 | | | |
| | onditions: | | | |
| 1) | The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority. | | | |
| 2) | Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy. | | | |
| 3) | The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind. | | | |
| 4) | All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy. | | | |
| 5) | A street opening permit(s) is required for your site. Please contact Carol Merritt ay 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.) | | | |
| 6) | As-built record information for sewer and stormwater service connections must be submitted to Public Services Engineering Section (55 Portland Street) and approved prior to issuance of a Certificate of Occupancy. | | | |
| 7) | All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy. | | | |
| 8) | The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions. | | | |
| 9) | Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintaned daily. | | | |
| 10 | The limits of allowable clearing shall be clearly marked with flagging or temporary fencing. Absolutely no clearing is to take place within, or encroach into the "do not disturb/no cut" zone. All conditions listed in the approved subdivision plan, as they relate to this lot shall be followed. | | | |
| 11 | This site must comply with the Landscape Preservation Standards outlined in the Land Use Ordinance, section 14-526(b)2a, stating that a minimum of 30% of existing trees, ten (10) inches DBH or greater, within the required setback, must be preserved. Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily. | | | |
| DE | RMIT ID: 2017-00054 Located at: 33 MORNINGSTAR LN (lot 3) CBL: 385A A033001 | | | |

12 A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.