#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

GRAY BENJAMIN J & SALLYANN GRAY JTS

Located at

23 GARSOE DR

**PERMIT ID:** 2015-02486

**ISSUE DATE:** 12/03/2015

**CBL:** 386A A002001

has permission to

Renovations to attic to create living space. Add dormer to rear of house and skylights on the other three hip roof sections.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Jeanie Bourke

Fire Official

**Building Official** 

Type:

## THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

single-family

Use Group: R

**Residential Single Family** 

3rd Floor

MUBEC/IRC 2009

# BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

### **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing Electrical Close-in Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

### City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: Date 2015-02486 10

Date Applied For: 10/13/2015

CBL:

386A A002001

Proposed Use:

Same: Single-Family Home

**Proposed Project Description:** 

Renovations to attic to create living space. Add dormer to rear of house and skylights on the other three hip roof sections.

**Dept:** Zoning **Status:** Approved w/Conditions **Reviewer:** Christina Stacey **Approval Date:** 10/20/2015

Note: R-2 zone Ok to Issue: ✓

No footprint or height expansion - renovation of attic into living space by adding one dormer and three

skylights.

#### **Conditions:**

- 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.
- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.
- 4) This is NOT an approval for an additional dwelling unit. You SHALL NOT add any additional kitchen equipment including, but not limited to items such as stoves, microwaves, refrigerators, or kitchen sinks, etc. Without special approvals.

**Dept:** Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Jeanie Bourke **Approval Date:** 12/03/2015 **Note:** Ok to Issue: ✓

#### **Conditions:**

- 1) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2.
- 2) Tempered safety glazing is required at all hazardous locations per IRC 2009 Sec. R308.4 and IBC 2009 Sec. 2406.4
- 3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 4) Connections and Fasteners to be installed per 2009 IBC Sec. 2304.9 and/or IRC Table R602.3(1)
- 5) There must be a 2" clearance maintained between the chimney and any combustible material, with draft stopping per code at each level
- 6) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.
- 7) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.