

# ELECTRICAL PERMIT

## City of Portland, Me.

*Longview Patricia W. Adams St  
WEDNESDAY  
5/22/96*



To the Chief Electrical Inspector, Portland Maine:  
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 4/17/96

LOCATION: 19 Alice Woods Dr

387-A-031

Permit # \_\_\_\_\_

OWNER Scott/Joan Smith

ADDRESS \_\_\_\_\_

								TOTAL EACH FEE			
<b>OUTLETS</b>											
	98	Receptacles (number of)	73	Switches		Smoke Detector		171	.20	34.20	
<b>FIXTURES</b>	60	incandescent	6	fluorescent				66	.20	13.20	
		fluorescent strip							.20		
<b>SERVICES</b>		Overhead				TTL AMPS TO	800			15.00	
	x	Underground					800	200		15.00	15.00
<b>TEMPORARY SERV.</b>		Overhead				AMPS OVER	800			25.00	
		Underground					800			25.00	
<b>METERS</b>	1	(number of)						1	1.00	1.00	
<b>MOTORS</b>		(number of)							2.00		
<b>RESID/COM</b>		Electric units							1.00		
<b>HEATING</b>	1	oil/gas units						1	5.00	5.00	
<b>APPLIANCES</b>	1	Ranges		Cook Tops		Wall Ovens			2.00		
		Water heaters		Fans	1	Dryers			2.00		
Disposals	1	Dishwasher		Compactors		Others (denote)		4	2.00	8.00	
<b>MISC. (number of)</b>		Air Cond/win		1		m/cro wave			3.00		
		Air Cond/cent							10.00		
		Signs							5.00		
		Pools							10.00		
		Alarms/res							5.00		
		Alarms/com							15.00		
		Heavy Duty							2.00		
		Outlets									
		Circus/Carnv							25.00		
		Alterations							5.00		
		Fire Repairs							15.00		
		E Lights							1.00		
		E Generators							20.00		
<b>TRANSFORMER</b>		Panels							4.00		
		0-25 Kva							5.00		
		25-200 Kva							8.00		
		Over 200 Kva							10.00		
							TOTAL AMOUNT DUE			76.40	
							MINIMUM FEE		25.00		
							MINIMUM FEE/COMMERCIAL		35.00		

INSPECTION: Will be ready \_\_\_\_\_ or will call  \_\_\_\_\_

CONTRACTORS NAME Freeport Refrigeration Co

ADDRESS 78 Desert Rd- Freeport

TELEPHONE 865-1150

MASTER LICENSE No. Kevin Sawyer #17013

LIMITED LICENSE No. \_\_\_\_\_

SIGNATURE OF CONTRACTOR

*Kevin Sawyer*

ELECTRICAL INSTALLATIONS—

INSPECTION: Service 5/22/96 by ALICE  
 Service called in 5/28/96  
 Closing-in 6/4/96 by ALICE

Permit Number 17013  
 Location 19 Alice woods Ln  
 Owner Scott Smith  
 Date of Permit 4/17/96  
 Final Inspection 5/29/96  
 City Inspector [Signature]

PROGRESS INSPECTIONS:  
5/22/96 (SERVICE)  
 Reinspect — 5/28/96 (SERVICE)  
6/4/96 (ROUGH-IN)  
6/6/96 (FINISH)  
6/8/96 (FINISH)

DATE:	REMARKS:
5/22/96	NEED MAIN DISCONNECT JUST INSIDE GARAGE (PVE & LB) NOT TO CODE (UNRUSED WIRES)!! VIOLATION WILL NOT APPROVE AS FS NOW
5/28/96	NEEDS LUG SCREWS & WIRE NUTS ground rod From main diss. make-up wires in (BOXES FOR ROUGH-IN)
6/4/96	ALL OK (ROUGH-IN)
6/6/96	NOT READY FOR C/O