


960427

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, May 20, 1996



388-B-023

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 33 Caron Street Use of Building Single Fam No. Stories 1 New Building Existing
Name and address of owner of appliance Tim Higgins 04005
Installer's name and address Provencher Oil Co., 139 Cleaves St., Biddeford Telephone 284-8068

General Description of Work

To install Cast iron peerless boiler

IF HEATER, OR POWER BOILER

Location of appliance cellar Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 18x 3 ft
From top of smoke pipe 18" From front of appliance 36" From sides or back of appliance 24"
Size of chimney flue 6" Other connections to same flue no
If gas fired, how vented? n/a Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Beckett Labelled by underwriters' laboratories? yes
Will operator be always in attendance? no Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe 1 3/4"
Location of oil storage cellar Number and capacity of tanks 1 275 gal
Low water shut off yes Make OEM 170 No. 1
Will all tanks be more than five feet from any flame? yes How many tanks enclosed? none
Total capacity of any existing storage tanks for furnace burners 275 gal

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustibile material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Roger Provencher - MS30001177- Master Oil Burner

mail

Amount of fee enclosed? \$40.00

APPROVED:

Signature of Inspector

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

- 1. 1 1/2" FULL PIPE
2. 1 1/4" VENT PIPE
3. END OF HEAD
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cut-off switch
9. Low water switch
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Oil traps
15. Instructed card
16. Oil leaks
17. Adequate ventilation
18. Brokers & Contractors
19. Thermal camera

Signature of Installer

Roger Provencher