SHED SPE

509 WAI

PORTLANI

(207)

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 12/08/14

Shed Happens, Inc. shed specifications:

4”x 4” Pressure Treated Skids

6’ + 8’ wide sheds have 2”x 4” Pressure Treated Floor Joists

10’ wide sheds have 2”x 6” Pressure Treated Floor Joists

¾”LP Shed ProStruct Tongue and Groove Flooring

2”x4” walls and roof framing 16” On Center

Metal Wall bracing in all pine board sheds

Collar ties on 10’ wide sheds, 4’ On Center

7/16” LP Roof and Wall Sheathing

35 year Architectural Roof Shingles

Aluminum Drip edge on all rakes and eaves

12” Acorn Door Hinges

(2) 8”x8” square aluminum gable vents (pine)

4’ ridge vent (vinyl + smartside)

SHED HEIGHTS :

Gable	Gambrel
6’ wide = 8’ 9”	6’ wide = N/A
8’ wide = 9’ 2”	8’ wide = 10’ 1”
10’ wide = 9’ 7”	10’ wide = 10’ 5”
12’ wide = 10’ 0”	12’ wide = 11’ 1”
14’ wide = 10’ 5”	14’ wide = 12’ 2”

Extended Gable

6’ wide =

8’ wide = 10’

10’ wide = 11’

12’ wide =

14’ wide =