

From: David Petrucci
To: Helen Donaldson
CC: Chris Pirone
Date: 9/4/2014 9:23 AM
Subject: Pamela Rd
Attachments: Pamela Rd.htm

Good morning,

Our comments at this point are that the street needs hydrants, hydrants should be approximately 500 feet apart. There are two hydrants on Alice each approximately 700+/- from where Pamela Rd will intersect. There is also a hydrant around the corner on Abby Ln about 250 ft from Pamela, the next hydrant is up at Crestview. I printed out a GIS with some measurements and markups and will scan that and email it to you.

David/Rico/....

David Petrucci, Fire Captain
Portland Fire Department
Fire Prevention Bureau
380 Congress Street
Portland, Maine 04101

Ph. 207-874-8400
petrucciid@portlandmaine.gov