

Request for Clarification of Information

Address: 38 Pamela Road

Permit #: 2017-00131

Date: 3/7/2017

Reviewer: Greg Gilbert

1. What are the sizes of the footings supporting the columns in the basement?
2' x 2'
2. What is the size of the drain pipes shown in the crushed stone? **4" pipe**
3. What type and size are the columns in the basement? **Per plan**
4. Provide manufacturer or stamped drawings for engineered trusses for roof. **See attached detail**
5. Provide more specific information on the roof covering. **Certainteed architectural Landmark Lifetime**
6. Provide connection and structural details for the Deck construction . **per plan page A0 deck / joist detail**
7. Specify what measure are being taken to provide fire separation between the garage and the house and the sleeping area. **Due to the truss system fire rated 5/8" sheetrock will be applied to common house wall, common garage to bedroom wall and garage ceiling**
8. Show height of handrail in section: **See attached amended plan**
9. Show location of CO and smoke detectors and specify requirements . **Per plan page A1**
10. Specify what type of sprinkler system is being used. **Dean and Allyn: an NFPA #13D wet pipe sprinkler system. Stands for National Fire Protection Association. 13 is the bible on sprinklers and D stands for domestic.**
11. Show the location and the size of the access to the attic : **See amended plan attached - 22" x 30" access in laundry room ceiling**
12. Provide details for chimney clearance and fire blocking: **N/A**