



GENERAL NOTES
 ALL DIMENSIONS ARE CENTER TO CENTER U/N
 ALL 2" AND SMALLER PIPE TO SCH 40 BLACK STEEL
 ALL SCREWED FITTINGS TO BE STD. WT. C.I. BLACK U/N
 ALL HANGER SPACING AND SIZES TO CONFORM TO NFPA #13.
 SUFFICIENT HEAT TO PREVENT FREEZING OF THE WET PIPE SPRINKLER SYSTEM AND REQUIRED INSULATION METHODS PER NFPA STANDARDS ARE REQUIRED TO BE FURNISHED BY THE BUYER/OWNER.

LEGEND
 ● 17-155" RELIABLE F1FR Q R BRASS PENDENTS BASEMENT
 ⊗ 15-165" RELIABLE RFC43 RES. WHITE CONCEALED PENDENT LIVING SPACE
 FF \bar{L} =XX FIN FLR TO CENTERLINE OF PIPE
 BJ \bar{L} =XX BOTTOM OF JOISTS TO CENTERLINE OF PIPE
 C \bar{L} =XX CEILING TO CENTERLINE OF PIPE
 ○ RISE OR DROP NIPPLE
 ⊕ RISER BETWEEN FLOORS

⊗ 15 RELIABLE RFC43
 155" RESIDENTIAL WHITE PENDENT CONCEALED LIVING SPACE
 1/2"x7/16" K=4.3
 ● 17 RELIABLE F1FR
 155" QR BRASS PENDENT BASEMENT
 1/2"x1/2" K=5.6

SYSTEM CLASSIFICATION
 A WET PIPE NFPA #13D
 SPRINKLER SYSTEM TO BE INSTALLED IN ALL AREAS OF THE RESIDENCE TO MEET NFPA, STATE, AND CITY OF PORTLAND CODES.

DEAN & ALLYN, INC.
 FIRE PROTECTION • SPECIAL HAZARD
 116 LEWISTON ROAD, GRAY, MAINE 04039
 (207)657-5646 FAX: (207)657-5647

		DANA A. STEWART NICET IV - #064544		TITLE 38 PAMELA ROAD PORTLAND, MAINE		NO. OF SPRINKLERS SHOWN ON THIS SHEET 32
REVISIONS		APPROVED BY	DATE	SURVEYED BY	HAK 5-31-17	NO. OF SPRINKLERS ON JOB 32
				DRAWN BY	HAK 5-31-17	CONTRACT NO. C171438
				CHECKED BY	DAS	
				AT DEAN & ALLYN, INC		
				SCALE	1/4"=1'-0"	
				SHEET NO.	1 OF 1	