



... Fire Protection by Computer Design

DEAN AND ALLYN, INC.
116 LEWISTON ROAD
GRAY MAINE
207 657 5646

Job Name : 38 PAMELA ROAD
Building :
Location : 38 PAMELA ROAD PORTLAND MAINE
System :
Contract : 1438
Data File : 38 Pamela Drive.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 38 PAMELA ROAD Date - 5-31-17
Location - 38 PAMELA ROAD PORTLAND MAINE
Building - System No. -
Contractor - DEAN AND ALLYN, INC. Contract No. - 1438
Calculated By - H. KING Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'
OCCUPANCY - RESIDENCE

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 9.1 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model RFC43
I Elevation at Highest Outlet - 10' Feet Size 7/16" K-Factor 4.3
G Note:CUSHION 16.2 PSI Temperature Rating 155
N

Calculation Gpm Required 26.3 Psi Required 43.4 At Test
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 1-20-17 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 55 Other Well
Flow (Gpm) - 100 Proof Flow Gpm
S Elevation - 0

P Location: ON PAMELA ROAD AT SITE

P
L Source of Information: PWD STATIC PRESSURE READING ON AN 8" CITY MAIN
Y

Final Calculations - Hazen-Williams

DEAN AND ALLYN, INC.
38 PAMELA ROAD

Page 2
Date 5-31-17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
1 to 2	12.97 12.97	1.049 120.0 0.0584	E 0.0	2.0 0.0	7.600 2.000	9.100 0.0		K Factor = 4.30	
2 to 10	13.37 26.34	1.049 120.0 0.2165	E 0.0	2.0 0.0	14.000 2.000	9.661 0.0		K Factor = 4.30	
10 to 11	26.34 0.0	0.2165 1.049 120.0 0.2165	0.0 T 5.0 0.0	16.000 24.800 5.000	3.464 13.125 0.0			Vel = 9.78	
11 to 12	26.34 0.0	0.2165 1.049 120.0 0.2165	0.0 E 2.0 0.0	29.800 9.300 2.000	6.452 19.577 4.331			Vel = 9.78	
12 to TR	0.0 26.34	1.049 120.0 0.2165	T 3E 6.0 0.0	10.500 11.000	26.355 0.0			Vel = 9.78	
TR to FF	0.0 26.34	1.049 120.0 0.2165	S 5.0 0.0	8.000 5.000	31.010 7.599			** Fixed Loss = 5	Vel = 9.78
FF to CTY	0.0 26.34	1.314 120.0 0.0723	T 2.974 0.0	60.000 2.974	41.424 -2.599			Vel = 6.23	
	0.0 26.34					43.378		K Factor = 4.00	

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.
38 PAMELA ROAD

Page 3
Date 5-31-17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	10.0	4.3	9.1	na	12.97	0.05	256	9.1
2	10.0	4.3	9.66	na	13.37	0.05	256	9.1
10	10.0		13.13	na				
11	10.0		19.58	na				
12	0.0		26.36	na				
TR	0.0		31.01	na				
FF	-6.0		41.42	na				
CTY	0.0		43.38	na				

The maximum velocity is 9.78 and it occurs in the pipe between nodes 2 and 10

Water Supply Curve C

DEAN AND ALLYN, INC.
38 PAMELA ROAD

Page 4
Date 5-31-17

City Water Supply:
C1 - Static Pressure : 60
C2 - Residual Pressure: 55
C2 - Residual Flow : 100

Demand:
D1 - Elevation : 4.331
D2 - System Flow : 26.337
D2 - System Pressure : 43.378
Hose (Demand) : _____
D3 - System Demand : 26.337
Safety Margin : 16.198

