DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

GENEVA VENTURES LLC

Located at

59 PAMELA RD (Lot 36)

PERMIT ID: 2017-00627

ISSUE DATE: 06/13/2017

389 E004001 CBL:

has permission to Construction of new 2-story single-family dwelling (1392 SF) with attached garage (400SF)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Brian Stephens

Fire Official

Building Official

Type:

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

single-family

Use Group: R

Single Family Dwelling Sprinkled

ENTIRE

MUBEC/IRC-2009

CBL: 389 E004001 **PERMIT ID:** 2017-00627 Located at: 59 PAMELA RD (Lot 36)

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Site VISIT

Final - DRC

Close-in Plumbing/Framing

Flectrical Close-in

Final - Electric

Final - Fire

Foundation/Backfill

Setbacks and Footings Prior to Pouring

Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

PERMIT ID: 2017-00627 **Located at:** 59 PAMELA RD (Lot 36) **CBL:** 389 E004001

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Single-family Proposed Project Description: Construction of new 2-story single-family dwelling (1392 SF) with attached garage (400SF)

Dept: Zoning **Status:** Approved w/Conditions **Reviewer:** Christina Stacey **Approval Date:** 05/05/2017

Note: R-2 zone Ok to Issue: ✓

Avg grade 112.76' - less than half of basement height is above - house is 2-story

Conditions:

- 1) Separate permits shall be required for future decks, sheds, pools, and/or garages.
- 2) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.
- 3) Prior to issuance of a Certificate of Occupancy, a copy of the recorded deed must be submitted to this office.
- 4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

Dept: Building Inspecti **Status:** Approved w/Conditions **Reviewer:** Brian Stephens **Approval Date:** 06/12/2017 **Note:** • Ok to Issue: ✓

Conditions:

- 1) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.
- 2) Insulation shall be installed to the equivalent R-value and windows to the equivalent U-factor for climate zone 6 per the IECC Tables
- 3) Beams shall be supported by posts and solid blocking to carry the load path to another beam, foundation or footing.
- 4) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.
- 5) Window sills in locations more than 72 inches from finished grade shall be a minimum of 24 inches above the finished floor of the room, unless a window fall prevention devices is installed in accordance with section IRC Sec. R612.3 or IBC Sec. 1405.13.2.

 Dept:
 Fire
 Status:
 Approved w/Conditions
 Reviewer:
 Jason Grant
 Approval Date:
 06/13/2017

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas.
 - 1. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 - 2.On each level of the dwelling unit, including basements but excluding attics and crawl spaces.
- 2) All construction shall comply with City Code, Chapter 10.
 - All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 24 and other applicable chapters All construction shall comply with 2009 NFPA 1, Fire Code.
 - This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4)
- 3) This review has determined that your project requires fire sprinkler system. A separate City of Portland One and Two-Family Sprinkler System Permit is required for all new sprinkler systems. This review does not include approval of system design or installation.

Sprinkler system installation shall comply with 2016 NFPA 13D.

PERMIT ID: 2017-00627 **Located at:** 59 PAMELA RD (Lot 36) **CBL:** 389 E004001

- 4) City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be nonionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
 - 1.Inside all sleeping rooms.
 - 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 - 3.On each level of the dwelling unit, including basements but excluding attics and crawl spaces.

In new construction per NFPA 101 2009 section 9.6.2.10.3 where 2 or more smoke detectors are required within a dwelling unit they shall be arranged so that the operation of any smoke alarm shall cause the alarm of all smoke alarms within the dwelling unit.

 Dept:
 DRC
 Status:
 Approved w/Conditions
 Reviewer:
 Philip DiPierro
 Approval Date:
 05/22/2017

 Note:
 Ok to Issue:
 ✓

Conditions:

- 1) The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.
- 2) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.
- 3) All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy.
- 4) A sewer permit is required for your project. Please contact Carol Merritt at 874-8300, ext. 8822. The Wastewater and Drainage section of Public Services must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.
- 5) A street opening permit(s) is required for your site. Please contact Carol Merritt ay 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)
- 6) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.
- 7) The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.
- 8) Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintaned daily.
- 9) The limits of allowable clearing shall be clearly marked with flagging or temporary fencing. Absolutely no clearing is to take place within, or encroach into the "do not disturb/no cut" zone. All conditions listed in the approved subdivision plan, as they relate to this lot shall be followed.
- 10 The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent mounumentation/pins identifying property corners.
- 11 This site must comply with the Landscape Preservation Standards outlined in the Land Use Ordinance, section 14-526(b)2a, stating that a minimum of 30% of existing trees, ten (10) inches DBH or greater, within the required setback, must be preserved. Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily.
- 12 A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.
- 13 Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy.

PERMIT ID: 2017-00627 **Located at:** 59 PAMELA RD (Lot 36) **CBL:** 389 E004001