



DEPARTMENT OF PUBLIC SAFETY  
OFFICE OF STATE FIRE MARSHAL  
FIRE SPRINKLER DIVISION  
**REQUIA RESIDENCE**

## LIMITED FIRE SPRINKLER PERMIT

Permit Number: LSP13012  
Status: Approved  
First Licensure: 03/20/2017  
Expiration Date: 09/19/2017

Street Location Address: 47 PAMELA ROAD  
LOT 35  
PORTLAND, ME 04103

### History

License Type	Start Date	End Date
LIMITED FIRE SPRINKLER PERMIT	03/20/2017	09/19/2017

### Contractor (1 record) hide

Name	Issue Date	License Number	License Status	License Cancel Date
MARK NIGRO RESIDENTIAL SPRINKLERS	03/20/2017	LSC666	Active	

### Managing Supervisor (1 record) hide

Name	Issue Date	License Number	License Status	License Cancel Date
BRENT KOTULA	03/20/2017	RMS929	Active	

## GENERAL INFORMATION

### Project Details

Type of Sprinkler Work: New System(s)  
Type of Building/Structure Work: New Construction

### Occupancy Classification

Primary Building Use: Residential  
Building Use Layout: Single Use

### Quantities

New fire sprinkler head(s): 29  
Dwelling units of each NFPA 13D: 1

### Standard(s) Used

NFPA 13D

### Design Method(s)

2 to 5 Head Calc

### Hazard Class(es)

Light

### System Type(s)

Wet

### Pump Information

### Water Test Results

Date of Last Test: 03/08/2017  
Static: 60  
Type of Water Test: Single Hydrant Test

Warning: Despite our efforts to be accurate, these pages may contain errors. We present this website to you with a good-faith representation that the information it contains is generally reliable. Information on this site should not be relied upon for legal purposes. If you need further information, we would encourage you to contact us directly (207-626-3880).

