Jonathan Rioux - Re: 26 Basket Ln

From: Jocelyne D <jocelyneinmaine@yahoo.com>
To: Jonathan Rioux <JRIOUX@portlandmaine.gov>
Date: 10/10/2013 8:19 AM
Subject: Re: 26 Basket Ln
Attachments: 10_9_2013-foundation11X17.pdf; 10_9_2013-fp11X17.pdf; 10_9_2013-Section11X17.pdf; building permit application city of portland.pdf

Hi Jonathan,

Thanks for your input on the plans. Please find the attached revision for your approval. After looking into it more, the cost of building the house will be $150,000. I have also enclosed a revised permit application and I will contact Gayle to pay the difference for the permit. Let me know if you have any questions.

Thank you,

Jocelyne

On Wednesday, October 9, 2013 10:16 AM, Jonathan Rioux <JRIOUX@portlandmaine.gov> wrote:
2013-01805.New Single Family

Please see the attached pdf file. and email the files with correction(s)/ clarification using your original file name.

Can you give me a call at 874.8702 when you receive this email?

- Stairway headroom shall be not less than 6 feet 8 inches measured vertically from the sloped plane adjoining the tread nosing or from the floor surface of the landing or platform.
- At the Basement level is there an emergency escape window or doorway?

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/18/13

Code Enforcement Officer/ Plan Reviewer

City of Portland
Planning and Urban Development Department
Inspection Services Division
389 Congress St. Rm 315
Portland, ME 04101
Office: 207.874.8702
Support Staff: 207.874.8703
jrioux@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/18/13