DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

Located at

17 BASKET LN

MCCALLUM CATHIE-ELLEN GOULD TRUSTEE/White Homes/James White

PERMIT ID: 2014-01425 **ISSUE DATE:** 07/16/2014

E: 07/16/2014 **CBL:**

: 390 A022001

has permission to New Single Family Home with attached 2 car garage

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Chris Pirone

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning Single family home Building InspectionsUse Group: R-3Type: 5BSingle FamilyENTIREMUBEC 2009Image: State State

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - DRC Setbacks and Footings Prior to Pouring Foundation/Backfill Close-in Plumbing/Framing Electrical - Residential Certificate of Occupancy/Final

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit			Permit No:	Date Applied For:	CBL:		
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874			2014-01425	06/30/2014	390 A022001		
			Proposed Project Description:				
			ngle Family Home	with attached 2 car	garage		
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 07/07/2014							
Note:					Ok to Issue: 🗹		
	Conditions:						
1)	1) As discussed during the review process, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Due to the proximity of the setbacks of the proposed structure, it may be required to be located by a surveyor.						
2)	2) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.						
3)) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.						
4)	4) Separate permits shall be required for future decks, sheds, pools, and/or garages.						
	ept: Building Status: Approved w/Conditions Review	er:	Tammy Munson	Approval Da	te: 07/16/2014 Ok to Issue: ☑		
С	onditions:						
1)	The design load spec sheets for any engineered beam(s) / Trusses must	be s	submitted to this of	ffice.			
2)) The stair construction shall comply with IRC Sec. R311 which includes, but is not limited to, a maximum riser height of 7-3/4" and a minimum net tread of 10", and nosings not less than 3/4" but not more than 1-1/4" where solid risers are required.						
3)	Tempered safety glazing is required at all hazardous locations per IRC	200	9 Sec. R308.4 and	IBC 2009 Sec. 2406	5.4		
4)	 Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all bedrooms, protecting the bedrooms, and on every level. 						
	The same is required for existing buildings, where permanent wiring is detectors are required. Verification of this will be upon inspection.	feas	sible; or at the very	y least battery operate	ed smoke		
5)	Egress size windows are required (1) in each bedroom per IRC Sec. R3	310					
6)) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to bedrooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.						
7)	The basement is NOT approved as habitable space. In order to change the use of this space, a code compliant Emergency Escape and Rescue Opening shall be installed per IRC Sec. R310. A separate permit is required.						
8)	This permit is approved based upon information provided by the applic approved plans requires separate review and approval prior to work.	cant	or design profession	onal. Any deviation f	rom the final		
9)	Septic field and extension inspection for bottom preparation/scarification horizon and erosion and sedimentation control measures.	on to	o verify removal o	f vegetation, establis	hed transitional		
Dept: Fire Status: Approved w/Conditions Reviewer: Chris Pirone Approval Date: 07/11/2014 Note: Ok to Issue: V							
Conditions:							
	Shall Comply with 2009 NFPA 101 Chapter 24 One- Two Family Occ All construction shall comply with City Code Chapter 10.	upar	acy.				

2)	 Single-station photoelectric smoke alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. Smoke alarms shall be installed in the following locations: (1) All sleeping rooms 						
	(2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms						
	 (3) On each level of the dwelling unit, including basements. Single-station Carbon Monoxide (CO) alarms are required. They shall be powered by the building's electrical service with battery backup and shall be interconnected. CO alarms shall be installed in the following locations: (1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms (2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces 						
3)	A sprinkler system shall be installed in accordance with NFPA 13D. A separate no fee One- or Two-family CITY Fire Sprinkler Permit is required.						
	ept: DRC Status: Approved w/Conditions Reviewer: Philip DiPierro Approval Date: 07/15/2014						
	ote: Ok to Issue: 🗹						
Conditions: The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these 							
1)	written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.						
2)	All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy.						
3)	3) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.						
4)	•) A street opening permit(s) is required for your site. Please contact Carol Merritt ay 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)						
5)) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.						
6)	In accordance with the approved subdivision plan, the owner is required to retain a licensed Maine land surveyor to lay out and certify the location and elevation of the foundation to ensure it conforms with the approved site plan.						
7)	The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.						
8)	A sewer permit is required for your project. Please contact Carol Merritt at 874-8300, ext . 8822. The Wastewater and Drainage section of Public Services must be notified five (5) working days prior to sewer connection to schedule an inspector for your site.						
9)	Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy.						
10	Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintaned daily.						
11	The limits of allowable clearing shall be clearly marked with flagging or temporary fencing. Absolutely no clearing is to take place within, or encroach into the "do not disturb/no cut" zone. All conditions listed in the approved subdivision plan, as they relate to this lot shall be followed.						
12	A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, driveway paving, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.						
13	Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily.						
14	In accordance with the approved subdivision plan, the owner is required to retain a Maine licensed civil engineer or landscape architect to provide construction phase services inspections. A report confirming periodic inspections must be submitted prior to the issuance of any certificate of occupancy.						

15 The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent mounumentation/pins identifying property corners.