



**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

|                       |                                 |                     |
|-----------------------|---------------------------------|---------------------|
| Permit No:<br>04-1208 | Date Applied For:<br>08/18/2004 | CBL:<br>392 A017001 |
|-----------------------|---------------------------------|---------------------|

|   |  |   |                         |
|---|--|---|-------------------------|
| Location of Construction:<br>215 Hope Ave | Owner Name:<br>Stacey Scott R &              | Owner Address:<br>215 Hope Ave                  | Phone:                  |
| Business Name:                            | Contractor Name:<br>Fielding's Oil & Propane | Contractor Address:<br>P.O. Box 364 Scarborough | Phone<br>(207) 883-3194 |
| Lessee/Buyer's Name                       | Phone:                                       | Permit Type:<br>HVAC                            |                         |

|                                |  |
|--------------------------------|--|
| Proposed Use:<br>single family | Proposed Project Description:<br>install a 100 lb propane cylinder |
|--------------------------------|--|

|                |                                  |                        |  |
|----------------|----------------------------------|------------------------|--|
| Dept: Zoning   | Status: Approved                 | Reviewer: Tammy Munson | Approval Date: 08/19/2004                        |
| Note:          |                                  |                        | Ok to Issue: <input checked="" type="checkbox"/> |
| Dept: Building | Status: Approved with Conditions | Reviewer: Tammy Munson | Approval Date: 08/19/2004                        |
| Note:          |                                  |                        | Ok to Issue: <input checked="" type="checkbox"/> |

1) The tank must be situated so that they are NOT subject to vehicular traffic.



**CITY OF PORTLAND, MAINE**  
Department of Building Inspections

Aug 13 2004

Received from Buildings

Location of Work 215 Home

Cost of Construction \$ 25.00

Permit Fee \$ 30.00

Building (I1)  Plumbing (I5)  Electrical (I2)  Site Plan (U2)

Other AVHC

CBL: 392 HCT

Check #: 5171

Total Collected \$ 30.00

**THIS IS NOT A PERMIT**

No work is to be started until PERMIT CARD is actually posted upon the premises. Acceptance of fee is no guarantee that permit will be granted. PRESERVE THIS RECEIPT. In case permit cannot be granted the amount of the fee will be refunded upon return of the receipt less \$10.00 or 10% whichever is greater.

WHITE - Applicant's Copy  
YELLOW - Office Copy  
PINK - Permit Copy

*Donna*



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

392 A017  
AUG 20 2004  
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 215 Hope Ave., Portland, ME. Use of Building Residential Date 8-13-04  
Name and address of owner of appliance Fielding's oil CO. Inc. P.O. Box 364  
Scarborough, ME, 04070-0364 "Scott Stacey owner of House"  
Installer's name and address William J. Fielding P.O. Box 364 Scarborough  
ME. 04070-0364 Telephone (207) 883-3194

### Location of appliance:

- Basement
- Attic
- Floor
- Roof
- outside

### Type of Fuel:

- Gas
- Oil
- Solid

propane

Appliance Name: 100lb cyl (Propane)

U.L. Approved  Yes  No

Will appliance be installed in accordance with the manufacture's installation instructions?  Yes  No

IF NO Explain: N/A

### The Type of License of Installer:

- Master Plumber # \_\_\_\_\_
- Solid Fuel # \_\_\_\_\_
- Oil # \_\_\_\_\_
- Gas # # PNT3784
- Other \_\_\_\_\_

### Type of Chimney:

- Masonry Lined  
Factory built N/A
- Metal  
Factory Built U.L. Listing # N/A
- Direct Vent  
Type N/A UL# \_\_\_\_\_

### Type of Fuel Tank

- Oil
- Gas  
propane

Size of Tank 100lb cyl (Propane)

Number of Tanks (1)

Distance from Tank to Center of Flame 10' + feet.

Cost Work \$25.00

### Approved

Fire: \_\_\_\_\_  
Ele.: \_\_\_\_\_  
Bldg.: \_\_\_\_\_

### Approved with Conditions

- See attached letter or requirement

Signature of Installer William J. Fielding - TR

White - Inspection    Yellow - File    Pink - Applicant's    Gold - Assessor's Copy

CHK# 5171