


DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Permit Number: 041022



Please Read Application And Notes, If Any, Attached

This is to certify that Brooks Kevin F & /Ron Dyn
has permission to Install Crown boiler and 275 on tank
AT 153 Hope Ave 392 B023001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must given and written permission procured before this building or part thereof loaded or closed-in. **HEAVY NOTICE IS REQUIRED.**

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____
Health Dept. _____
Appeal Board _____
Other _____ DepartmentName

[Handwritten Signature]
7/22/04
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1022	Issue Date:	CBL: 392 B023001
-----------------------	-------------	---------------------

Location of Construction: 153 Hope Ave	Owner Name: Brooks Kevin F &	Owner Address: 72 Bramblewood Dr	Phone:
Business Name:	Contractor Name: Ron Dymond	Contractor Address: 50 Outlook Drive Turner	Phone 2072252024
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	Zone:

Past Use: Single family home	Proposed Use: Single family home w/crown boiler and 275 gallon tank	Permit Fee: \$111.00	Cost of Work: \$10,000.00	CEO District: 5
---------------------------------	--	-------------------------	------------------------------	--------------------

FIRE DEPT: <i>N/A</i>	<input type="checkbox"/> Approved <input checked="" type="checkbox"/> Denied	INSPECTION: Use Group: <i>U</i> Type: <i>Heating</i> <i>BCA Mechanical</i> <i>1993</i>
Signature:		Signature: <i>[Signature]</i>

Proposed Project Description:
Install Crown boiler and 275 gallon tank

PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action:	<input type="checkbox"/> Approved	<input type="checkbox"/> Approved w/Conditions
Signature:		Date:

Permit Taken By: jodinea	Date Applied For: 07/22/2004	Zoning Approval	
-----------------------------	---------------------------------	------------------------	--

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Special Zone or Reviews
<input type="checkbox"/> Shoreland
<input type="checkbox"/> Wetland
<input type="checkbox"/> Flood Zone
<input type="checkbox"/> Subdivision
<input type="checkbox"/> Site Plan
Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/>
late:

Zoning Appeal
<input type="checkbox"/> Variance
<input type="checkbox"/> Miscellaneous
<input type="checkbox"/> Conditional Use
<input type="checkbox"/> Interpretation
<input type="checkbox"/> Approved
<input type="checkbox"/> Denied
late:

Historic Preservation
<input type="checkbox"/> Not in District or Landmark
<input type="checkbox"/> Does Not Require Review
<input type="checkbox"/> Requires Review
<input type="checkbox"/> Approved
<input type="checkbox"/> Approved w/Conditions
<input type="checkbox"/> Denied
late:

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.


SIGNATURE OF APPLICANT ADDRESS DATE PHONE

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE DATE PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT



392 BO 23

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 153 Hope Lane Use of Building Residence Date 7/21/04
 Name and address of owner of appliance Kevin Brooks
153 Hope Lane Portland
 Installer's name and address Ron Dymond
50 Outlook Drive Turner, ME 04282 Telephone 207 225 2024

Location of appliance:
 Basement Floor
 Attic Roof

Type of Fuel:
 Gas Oil Solid

Appliance Name: Crown Boiler
 U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

Master Plumber # _____
 Solid Fuel # _____
 Oil # MS 3000 8260
 Gas # _____
 Other _____

Type of Chimney:

Masonry Lined
 Factory built _____

Metal
 Factory Built U.L. Listing # _____

Direct Vent
 Type _____ uL# _____

Type of Fuel Tank

Oil
 Gas

Sue of Tank 275 gallon

Number of Tanks one

Distance from Tank to Center of Flame 15' feet.

Cost of Work: \$ 10,000

Permit Fee: \$ 11.00

Approved

Approved with Conditions

Fire: _____
 Ele.: _____
 Bldg.: _____

See attached letter or requirement

Signature of Installer Ronald P. Dymond

Inspector's Signature _____ Date Approved _____

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 04-1022	Date Applied For: 07/22/2004	CBL: 392 B023001
------------------------------	--	----------------------------

Location of Construction: 153 Hope Ave	Owner Name: Brooks Kevin F &	Owner Address: 72 Bramblewood Dr	Phone:
Business Name:	Contractor Name: Ron Dymond	Contractor Address: 50 Outlook Drive Turner	Phone (207) 225-2024
Lessee/Buyer's Name	Phone:	Permit Type: HVAC	

Proposed Use: Single family home w/crown boiler and 275 gallon tank	Proposed Project Description: Install Crown boiler and 275 gallon tank
---	--

Dept: Zoning	Status: Approved	Reviewer: Tammy Munson	Approval Date: 07/22/2004
Note:	Ok to Issue: <input checked="" type="checkbox"/>		

Dept: Building	Status: Approved with Conditions	Reviewer: Tammy Munson	Approval Date: 07/22/2004
Note:	Ok to Issue: <input checked="" type="checkbox"/>		
1) Installation shall comply with 1993 BOCA Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules			