

Project Scope:

Photovoltaic system consisting of (22) 305W modules flush mounted to asphalt shingle roof with (1) single phase grid tied inverter and interconnected with supply side connection in the main service panel.

Grid Tied Photovoltaic Array

DC Rating: 6.71 kW

AHJ: City of Portland

Equipment Specifications:

- (22) Modules: Qcell Q.PEAK-G4.1 305W
- (01) Inverter: SE6000H-US
- (22) SolarEdge P320 DC Optimizers
- Racking: Ironridge XR100 Aluminum Rail
- Roof Attachment: Aluminum L-Feet Secured with SS Lag Screws, 3" x 5/16"

General Installation Notes:

- Installation follows all fire code setbacks per ordinances of the City of Portland.
- All work will comply with the ordinances of the City of Portland.
- Rooftop attachments are sealed and spaced to evenly distribute loads.
- All photovoltaic equipment is tested and listed by a recognized laboratory.
- Grounding and bonding procedures for all photovoltaic equipment comply with NEC 2014.
- Rapid shutdown requirements are in accordance with NEC 690.12.
- Conduit between subarrays, combiners, and disconnects shall take the shortest reasonable path.
- Space requirements for electrical equipment shall comply with NEC Article 110.
- Any plaques shall be of metal or plastic construction, with engraved or machine printed lettering, or electro-plating, in a red background with white lettering, a minimum of 3/8" height and all capital letters.

Compliance Codes:

- City of Portland Building Code
- City of Portland Mechanical Code
- City of Portland Electrical Code
- City of Portland Plumbing Code
- City of Portland Fire Code
- 2014 National Electric Code (NFPA 70)
- ASCE/ANSI 7-05 Minimum Design Loads for Buildings and Other Structures

Solar Rendering:



Sheet List:	
Sheet No.	Sheet Title
000	COVER
A01	SITE PLAN



142 Presumpscot Street
Portland, ME 04103
(207) 221-6342

Customer Name:

Dirane Kelekyan
48 Overset Rd.
Portland, ME 04103

System Type:

6.71 kW_{DC}
Solar Photovoltaic System

Designed by:	GJD
Date:	2018-JAN-16
Rev.	0

COVER

000

© Copyright ReVision Energy

This diagram is provided as a service and is based on the understanding of the information supplied. It is subject to change based on actual conditions, applicable edition of the National Electric Code, and local governmental authorities.

NOT FOR CONSTRUCTION

Equipment Specifications:


(22) Modules: Qcell Q.PEAK-G4.1 305W

(01) Inverter: SE6000H-US

(22) SolarEdge P320 DC Optimizers

Racking: Ironridge XR100 Aluminum Rail

Roof Attachment: Aluminum L-Feet Secured with SS Lag Screws, 3" x 5/16"



Proposed Photovoltaic Array, 10.14 kW_{DC}



142 Presumpscot Street
Portland, ME 04103
(207) 221-6342

Customer Name:

Dirane Kelekyan
48 Overset Rd.
Portland, ME 04103

System Type:

6.71 kW_{DC}
Solar Photovoltaic System

Designed by: GJD

Date: 2018-JAN-16

Rev. 0

SITE PLAN

A01

© Copyright ReVision Energy

This diagram is provided as a service and is based on the understanding of the information supplied. It is subject to change based on actual conditions, applicable edition of the National Electric Code, and local governmental authorities.