## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

HAAS JOHN M JR & SHERYL D HAAS JTS

Located at

104 ROARING BROOK RD

**PERMIT ID: 2015-03068 IS** 

**ISSUE DATE:** 01/08/2016

**CBL:** 395 K031001

has permission to Demo wall with three windows and replace with two windows and re-frame.

Demo wall from kitchen to living room (non-load bearing wall to be removed.)

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

**Building Official** 

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

## Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing Electrical Close-in Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 2015-03068 12/22/2015 395 K031001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Single Family Demo wall with three windows and replace with two windows and re-frame. Demo wall from kitchen to living room (non-load bearin wall to be removed.) Reviewer: Tammy Munson 01/05/2016 **Dept:** Zoning **Status:** Approved w/Conditions **Approval Date:** Ok to Issue: Note: **Conditions:** 1) This permit approves interior work only. **Reviewer:** Tammy Munson 01/05/2016 Dept: Building Inspecti **Status:** Approved w/Conditions **Approval Date:** Note: Ok to Issue: ✓ **Conditions:** 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final

approved plans requires separate review and approval prior to work.