

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

EFRON JACOB B & KARLI A EFRON JTS

Located at

39 PINELOCH DR

PERMIT ID: 2016-02585

ISSUE DATE: 11/29/2016

CBL: 396 D013001

has permission to **Remove 17 feet of wall, install a steel beam, and create new one-story interior space (62 sf) from the existing rear covered porch.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Doug Morin

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

single-family

Building Inspections

Use Group:

Single Family Residence

ENTIRE

MUBEC/IRC 2009

Type:

Fire Department

PERMIT ID: 2016-02585

Located at: 39 PINELOCH DR

CBL: 396 D013001

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical Close-in

Final Inspection

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02585	Date Applied For: 10/03/2016	CBL: 396 D013001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Single-Family Home		Proposed Project Description: Remove 17 feet of wall, install a steel beam, and create new one-story interior space (62 sf) from the existing rear covered porch.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 11/04/2016
Note: R-2 zone Lot size 13,698 sf, meets 10,000 sf min Setbacks are all scaled from the tax map since a plot plan was not submitted: Front yard 25' min, existing house 36' - OK Rear yard 25' min, new enclosure >75' - OK Left side yard 14' min - new enclosure >18' - OK Lot coverage OK		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
<ol style="list-style-type: none"> 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 2) Because the setback approvals were based on the tax maps, which are not necessarily an accurate representation of the actual property lines, the property must be clearly identified prior to pouring concrete and compliance with the required setbacks must be established. Property lines may need to be located by a surveyor. 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Doug Morin	Approval Date: 11/29/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
<ol style="list-style-type: none"> 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 2) Insulation shall be installed to the equivalent R-value and windows to the equivalent U-factor for climate zone 6 per the IECC Tables 3) Wiring installations for this project or occupancy shall comply with the 2014 National Electric Code. Existing conditions for new occupancies will be required to be upgraded to prescribed standards. Loading calculations may need to be provided prior to any electrical installations. Please contact the City electrical inspectors with any questions. 4) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery. 5) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level. The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection. 6) Connections and Fasteners to be installed per 2009 IBC Sec. 2304.9 and/or IRC Table R602.3(1) 7) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. 				