

5-22-01: Checked Side Setback @ 11+ FT.

REAR APPROX. 62'; Discussed Code Compliance; Elect Requirements. (U6)

7/12/01 Inspected with Mike Collins. Pool pump not UL listed for permanent installation, ^{OK} plug 3 wire GFI, ~~OK~~ receptacle protection OK ^{OK} - must move pump to min. 3' of plug in. Pool, chain at RR Tie & repair at Rock wall must be bonded. ??

Need Receptacle at Garage for max 20' requirement. ^{OK}
Need to protect electrical conduit at ~~the~~ Receptacle area to meet 18" or 12" (w/concrete) depth. Trench to house ok to backfill. Deck around Pool w/ barrier not complete - advised homeowner using pool at own Risk & plastic retractable ladder was not sufficient protection. Owner will call when pump & barriers are ready JB

4/12/02 Elec ok

Pool ok except - no ladder protection (K)

4/26/02 N.O.V. ^{owner sent 4/26/02} re: 5/26/02 (K)

5/23/02 - No Ladders to be used - owner is a "Tall" single male who chooses to climb over 48" pool wall - discussed w/MJN ok (K) - Letter Sent (K)

ELECTRICAL PERMIT

City of Portland, Me.

DAVE / JON
Area 2
Single Family



MW

To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 2/17/00
 Permit # 135
 CBL# 397-C-008

SITE LOCATION: 744 Allen Ave

OWNER Dean Manooqian TENANT _____

							TOTAL EACH FEE		
OUTLETS	Receptacles		Switches		Smoke Detectors			.20	
FIXTURES	incandescent		fluorescent		Strips			.20	
SERVICES	Overhead		Underground		TTL AMPS <800	1	15.00	15.00	
	Overhead		Underground		<u>100AMP</u> >800		25.00		
Temporary Service	Overhead		Underground		TTL AMPS		25.00		
							25.00		
METERS	(number of)	<u>1</u>				1	1.00	1.00	
MOTORS	(number of)						2.00		
RESID/COM	Electric units						1.00		
HEATING	oil/gas units		Interior		Exterior		5.00		
	APPLIANCES	Ranges	Cook Tops		Wall Ovens		2.00		
	Insta-Hot		Water heaters		Fans		2.00		
	Dryers		Disposals		Dishwasher		2.00		
	Compactors		Spa		Washing Machine		2.00		
	Others (denote)						2.00		
MISC. (number of)	Air Cond/win						3.00		
	Air Cond/cent				Pools		10.00		
	HVAC		EMS		Thermostat		5.00		
	Signs						10.00		
	Alarms/res						5.00		
	Alarms/com						15.00		
	Heavy Duty(CRKT)						2.00		
	Circus/Carnv						25.00		
	Alterations						5.00		
	Fire Repairs						15.00		
	E Lights						1.00		
	E Generators						20.00		
	PANELS	Service		Remote		Main		4.00	
	TRANSFORMER	0-25 Kva						5.00	
		25-200 Kva						8.00	
Over 200 Kva							10.00		
					TOTAL AMOUNT DUE				
MINIMUM FEE/COMMERCIAL 35.00					MINIMUM FEE		25.00	<u>25</u>	

INSPECTION: Will be ready 2/23/00 11:00 or will call _____

CONTRACTORS NAME T. A. NAPOLITANO MASTER LIC. # 7765
 ADDRESS P.O. Box 2301 So. LIMITED LIC. # _____
 TELEPHONE 799-0538

SIGNATURE OF CONTRACTOR T. A. Napolitano