

10/3/01 See summital for Cross Section - shows Gable  
Roof w/ 2x8 Rafters. Garage Doors are in Gable End JB  
Also see Slab Specs JB

17 Summit St  
398-A-003

10/19/01 - setback inspection

Front - 25' leg - 40 FT +

Side - 12' leg - 16 FT -

Rear 25' leg - 70 FT +

Forms are in OK to pour concrete. Jan M

10/25/01 - Slab in and meets code - OK to start building  
new garage.  
Jan M.

1/29/02 - Final - Complete as per plans