

Michael and Linda Huitt
47 Summit Street
Portland, ME 04103

Re Application No: 2015-00472
Permit ID: 2015-00465
Amendment to existing permit
Plan P1 Plumbing Plan Master Bathroom

Reason for revision:

Demolition of current bathroom revealed safety and structural concerns necessitating revision of plumbing plan.

Re: Existing vent.

Closet flange (cast iron) rusted and broken beyond repair.

Closet elbow (cast Iron) broken beyond repair.

Evidence of water infiltration around existing vent causing damage to exterior wall structure and insulation.

Resolution:

Remove existing vent.

Connect master bathroom waste lines to already permitted guest bathroom drain.

Install additional vent within master bathroom to service toilet and lavatory.