




Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions

Date: 08/18/14



**Outdoor Units**

Located on the Southwestern gable end of the home and will be mounted on a wall bracket.

Weight of each unit is 88 lbs.

**Indoor Unit – 1<sup>st</sup> Fl.**

15,000 Btu/hr - Located in the main living area high up on the exterior wall

Weight of unit is 22 lbs. Unit to be mounted to wall framing with 2.5" fasteners sufficient to support the unit.

**Notes:**

Home is built of traditional wood framing and is sufficient to support the additional load of the equipment being installed.

ReVision Energy	HVAC Equipment Layout				
	Peter Chadbourne				
142 Presumpscot Street Portland, Maine, 04097 207-221-6342	80 Racine Ave., Portland, ME 04103				
DATE 7/31/2014	DRAWN BY Geoff Sparrow	PAGE 1 of 1	DWG# 1	Rev. 0	