

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical code and the following specification:

Date 21 January 1997

Permit # 14229

LOCATION: 26 Racine Ave

OWNER Baystate Development ADDRESS _____

TOTAL EACH FEE

OUTLETS		RECEPTACLES		SWITCHES		SMOKE DETECTOR	80	20	.20	16.00
FIXTURES		(number of)								
		incandescent		fluorescent				20	.20	4.00
		fluorescent strip							.20	
SERVICES		Overhead				TTL AMPSTO	800		15.00	
		Underground					800	100	15.00	15.00
TEMPORARY SERV.		Overhead				AMPS OVER	800		25.00	
		Underground					800		25.00	
METERS		(number of)						1	1.00	1.00
MOTORS		(number of)							2.00	
RESID/COM		Electric units							1.00	
HEATING		oil/gas units							5.00	
APPLIANCES		Ranges	1	Cook Tops		Wall Ovens			2.00	
		Water heaters		Fans	2	Dryers	1		2.00	
Disposals	1	Dishwasher	1	Compactors		Others (denote)			2.00	12.00
MISC. (number of)		Air Cond/win							3.00	
		Air Cond/cent							10.00	
		Signs							5.00	
		Pools							10.00	
		Alarms/res							5.00	
		Alarms/com							15.00	
		Heavy Duty							2.00	
		Outlets								
		Circus/Carnv							25.00	
		Alterations							5.00	
		Fire Repairs							15.00	
		E Lights							1.00	
		E Generators							20.00	
		Panels							4.00	
	TRANSFORMER		0-25 Kva							5.00
		25-200 Kva							8.00	
		Over 200 Kva							10.00	
						TOTAL AMOUNT DUE				
						MINIMUM FEE/COMMERCIAL	35.00	MINIMUM FEE	25.00	48.00

INSPECTION: Will be ready 1/22 AM or will call _____

CONTRACTORS NAME Jeff Hight

ADDRESS 17 Racine Ave Ptld, ME

TELEPHONE 797-9693

MASTER LICENSE No. 14229

LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

ELECTRICAL INSTALLATIONS

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection 2/25/97

By Inspector [Signature]

INSPECTION: Service 2/4/97 by [Signature]
 Service called in 2/4/97
 Closing-in 1/22/97 by [Signature]

PROGRESS INSPECTIONS: 1/22/97 (Closing)
1/24/97 trench
2/3/97 (SERVICE)
2/25/97 (Final)
 _____ | _____ |
 _____ | _____ |

DATE:	REMARKS:
	Crimp sleeves used on current carrying conductors (Legal?)
<u>1/24/97</u>	trench needs installing type (1") Below grade
<u>2/3/97</u>	No box not installed on connections, need use GERT RAIL screws holding meter on wall <u>[Signature]</u> Not ready
<u>2/4/97</u>	OK
<u>2/25/97</u>	Power wires & clip (pipe & SE) @ meter