City Of Portland Inspection Services

Memo

To: Dwight Brackett

From: Mike Nugent **Date:** 06/18/2002

Re: 15-19 Haskell St. (339 F010)

The following information must be provided prior to the release of Permit #020515 for a single family home:

- 1) Bearing wall detail
- 2) Steel beam info
- 3) Interior stairway handrail / guard rail detail
- 4) Front stairway landing dimensions, treads risers guar detail
- 5) Egress windows?
- 6) Tell me a bit more about the "all fuel" chimney (product info, UL listing etc.,
- 7) Union between the Steel beam and the 3- 2" X 10 " girder
- 8) How are we compensating for the opening in the floor for the "chimney"?