

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date _____
 Permit # 2010-4296
 CBL# 400-D-19

LOCATION: RAY STREET METER MAKE & # _____
 CMP ACCOUNT # _____ OWNER Wentzell Builders
 TENANT _____ PHONE # _____

TOTAL EACH FEE

OUTLETS	50	Receptacles	20	Switches	6	Smoke Detector	.20	15.20	
FIXTURES	18	Incandescent		Fluorescent		Strips	.20	3.60	
SERVICES	1	Overhead		Underground		TTL AMPS <800	15.00	15.00	
		Overhead		Underground		>800	25.00		
Temporary Service		Overhead		Underground		TTL AMPS	25.00		
							25.00		
METERS	1	(number of)					1.00	1.00	
MOTORS		(number of)					2.00		
RESID/COM		Electric units					1.00		
HEATING		oil/gas units		Interior		Exterior	5.00		
APPLIANCES	1	Ranges		Cook Tops		Wall Ovens	2.00	2.00	
		Insta-Hot		Water heaters	2	Fans	2.00		
		Dryers		Disposals	1	Dishwasher	2.00	2.00	
		Compactors		Spa	1	Washing Machine	2.00		
		Others (denote)					2.00		
MISC. (number of)		Air Cond/win					3.00		
		Air Cond/cent				Pools	10.00		
		HVAC		EMS		Thermostat	5.00		
		Signs					10.00		
		Alarms/res					5.00		
		Alarms/com					15.00		
		Heavy Duty(CRKT)					2.00		
		Circus/Carnv					25.00		
		Alterations					5.00		
		Fire Repairs					15.00		
		E Lights					1.00		
		E Generators					20.00		
		PANELS		Service	1	Remote		Main	4.00
TRANSFORMER		0-25 Kva					5.00		
		25-200 Kva					8.00		
		Over 200 Kva					10.00		
TOTAL AMOUNT DUE									
MINIMUM FEE/COMMERCIAL 55.00							MINIMUM FEE	45.00	

CONTRACTORS NAME Alan Brown MASTER LIC. # MS 60013871
 ADDRESS PO Box 530 - Sanford, Me LIMITED LIC. # _____
 TELEPHONE 324-6154

SIGNATURE OF CONTRACTOR [Signature]

ELECTRICAL INSTALLATIONS—

Permit Number _____

Location _____

Owner _____

Date of Permit _____

Final Inspection _____

By Inspector _____

INSPECTION: Service _____ by _____

Service called in _____

Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:

REMARKS:

8/10/2010

Needs to install Groundy Block + Silicone Tite Water Tight Connector
Electrician will call when completed. BKL

8/13/2010

Service OK BKL

21 D 002