

Fenstermacher, Dave

From: David Margolis-Pineo <dmp@portlandmaine.gov>
Sent: Tuesday, March 15, 2016 12:23 PM
To: Angel Robinson
Cc: Fenstermacher, Dave; Jeff Levine; Barbara Barhydt; Helen Donaldson; Shukria Wiar; Jean Fraser; Rick Knowland; Nancy Gallinaro; Benjamin Pearson; Rachel Smith; John Emerson; Scott Firmin
Subject: Wastewater Capacity Application Approval for 1363 Washington Ave - Taco Bell

March 15, 2016

RE: The Capacity to Handle Wastewater Flows from 1363 Washington Ave – Proposed Taco Bell

Dear Angel: (angel.robinson@guggenheimpartners.com)

The Department of Public Works, which includes the Water Resource Division have reviewed and determined that the downstream sewers from 1363 Washington Ave has the capacity to convey the estimated 1,416 gpd of proposed wastewater which will be generated from this facility.

The Department is aware that a 1,000 gallon grease interceptor is proposed with this project. The addition of this device is much appreciated.

If the City can be of further assistance, please call me at 874-8850 or 400-6695.

Sincerely,

CITY OF PORTLAND

David Margolis-Pineo

David Margolis-Pineo

<u>Anticipated Wastewater Flows from the Proposed Taco Bell at 1363 Washington Ave:</u>	
Three Meals per Day with 40 Seats @ 30 gpd/seat =	1,200 gpd
18 Employees @12 gpd/employee =	<u>216</u>
Total	1,416 gpd

Jeffrey Levine, Director, Department of Planning and Urban Development, City of Portland

Barbara Barhydt, Development Review Services Mgr., Dep't. of Planning and Urban Development, City of Portland

Nell Donaldson, Department of Planning and Urban Development, City of Portland

Shukria Wiar, Planner, Department of Planning and Urban Development, City of Portland

Jean Fraser, Planner, Department of Planning and Urban Development, City of Portland

Rick Knowland, Planner, Department of Planning and Urban Development, City of Portland

Nancy Gallinaro, Water Resources Manager

Benjamin N. Pearson, Industrial Pretreatment Coordinator, City of Portland

Rachel Smith, Assistance Industrial Pretreatment Coordinator, City of Portland

John Emerson, Wastewater Coordinator, City of Portland

Scott Firmin, Director of Wastewater, Portland Water District

David Fenstermacher - VHB

--
David Margolis-Pineo
Deputy City Engineer
Department of Public Services
55 Portland St.
Portland, ME 04101
Office 207-874-8850
Fax 207-874-8852
Cell 207-400-6695
dmp@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.