Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/26/15

NFPA 13R sprinkler check list

- ☐ Is this check list applicable? _____
- ☐ What edition of NFPA 13R is the designed to? _____
- ☐ Building construction type: _____
- ☐ Will the sprinkler system provide complete or partial coverage of the building? _____
- ☐ Will covered exterior balconies, decks and ground floor patios be sprinklered? _____
- ☐ Size of riser assembly: _____
- ☐ Fire department connection- number of 2 ½" inlets: _____
- ☐ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: _____
- ☐ Is the nearest fire hydrant within 100 ft. of the FDC? _____
- ☐ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? _____

NFPA 13 sprinkler check list

- ☒ Is this check list applicable? _____
- ☒ What edition of NFPA 13 is the designed to? 2007
- ☒ Building construction type: CONCRETE/STEEL
- ☒ Will the sprinkler system provide complete or partial coverage of the building? COMPLETE
- ☒ System type (See NFPA 13:3.4): WET
- ☐ NFPA 13 Occupancy Classification (Hazard): LIGHT/ORDINARY I
- ☒ Is the structure high-rise (see NFPA 101:3.3.32.7)? NO
- ☒ Size of riser assembly: EXISTING 6"
- ☒ Fire department connection- number of 2 ½" inlets: 4" STORZ EXISTING
- ☒ Electrical supervision will be provided via the fire alarm system per NFPA 101:9.7.2: EXISTING/YES
- ☒ Is the nearest fire hydrant within 100 ft. of the FDC? YES
- ☒ The completed *Contractor's Material and Test Certificate for Aboveground Piping* shall be provided at the completion of the job? _____

NFPA 14 standpipe check list

- ☐ Is this check list applicable? _____
- ☐ What edition of NFPA 14 is the designed to? _____

Building Inspections Division • 389 Congress Street • Portland, Maine 04101 • (207) 874-8703 • FACSIMILE (207) 874-8716 • TTY (207) 874-8936