



GENERAL NOTES:

- 1. ALL NEW ELECTRICAL CONDUCTORS SHALL BE PLENUM RATED.

TECHNICAL NOTES:

- ① PROVIDE 20AMP CIRCUIT TO SPARE CIRCUIT BREAKER IN CLOSEST ELECTRICAL PANELBOARD. IF NO SPARE CIRCUIT BREAKER IS AVAILABLE, CONNECT TO CLOSEST EXISTING RECEPTACLE CIRCUIT WITH SPARE CAPACITY.

REV.	DESCRIPTION	DATE
1	REISSUED	10.20.10
0	CONSTRUCTION DOCS	10.18.10

CONSTRUCTION DOCUMENTS
10.18.10

PROJECT NORTH

10.22.10

WBRC
ARCHITECTS • ENGINEERS

BANGOR, MAINE 04901-4311
PORTLAND, MAINE 04107-7741
SARASOTA, FLORIDA 941-556-0757
WWW.WBRC.COM

PROJECT:
MARTIN'S POINT HEALTH CARE
NORTHPORT PLAZA HVAC
RENOVATIONS
PORTLAND, ME

SHEET TITLE:
SECOND FLOOR ELECTRICAL
PLAN

SHEET TITLE: 3626.00 - E-102

PROJECT No. 3626.00

SCALE: AS NOTED

DATE: RLR

DESIGNED BY: LJM

CHECKED BY: RLR

SHEET No. E-102

DATE OF RECORD: 15