



GENERAL NOTES:

- 1. ALL NEW ELECTRICAL CONDUCTORS SHALL BE PLENUM RATED.

TECHNICAL NOTES:

- ① PROVIDE 20AMP CIRCUIT TO SPARE CIRCUIT BREAKER IN CLOSEST ELECTRICAL PANELBOARD. IF NO SPARE CIRCUIT BREAKER IS AVAILABLE, CONNECT TO CLOSEST EXISTING RECEPTACLE CIRCUIT WITH SPARE CAPACITY.

REV.	DESCRIPTION	DATE
1	REISSUED	10.20.10
0	CONSTRUCTION DOCS	10.18.10

CONSTRUCTION DOCUMENTS
10.18.10

PROJECT NORTH

10.22.10

WBRC
ARCHITECTS • ENGINEERS

BANGOR, MAINE 04901-4511
PORTLAND, MAINE 04106-7741
SARASOTA, FLORIDA 941-556-0757
WWW.WBRC.AE.COM

PROJECT:
MARTIN'S POINT HEALTH CARE
NORTHPORT PLAZA HVAC
RENOVATIONS
PORTLAND, ME

SHEET TITLE:
THIRD FLOOR ELECTRICAL
PLAN

PROJECT No. 3626.00 **GRAPHIC SCALE:** 0' 1'

SCALE: AS NOTED

DATE: 10/18/10

DESIGNED BY: RLR **CHECKED BY:** RLR

DATE OF RECORD: 10/18/10

SHEET No. **E-103**

A1 THIRD FLOOR ELECTRICAL PLAN

1/8" = 1'-0"