## DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

LL BEAN INC

Located at

43 NORTHPORT DR (Unit 3)

**PERMIT ID:** 2015-01926

**ISSUE DATE:** 09/02/2015

**CBL:** 401 A005043

has permission to For the installation of an Addressable Fire Alarm System (Notifier by Honeywell)

for "LL Bean, Inc." (Chesure Building - Unit 3).

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

**Building Official** 

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

## Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 2015-01926 08/07/2015 401 A005043 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Same: Office Space "L.L. Bean, Inc." (Cheshire Building - Unit 3) For the installation of an Addressable Fire Alarm System (Notifier by Honeywell) for "LL Bean, Inc." (Chesure Building - Unit 3). Reviewer: Tammy Munson **Dept:** Zoning Status: Approved **Approval Date:** 08/11/2015 Ok to Issue: Note: **Conditions: Dept:** Fire **Status:** Approved w/Conditions Reviewer: Craig Messinger 09/02/2015 **Approval Date:** Note: Ok to Issue: ✓

**Conditions:** 

- 1) All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".
- 2) The fire alarm system shall have a new fire alarm inspection sticker.
- 3) The installation shall comply Protection.with the following:

City of Portland Chapter 10, Fire Prevention and

NFPA 1, Fire Code (2009 edition), as amended by City Code;

NFPA 101, Life Safety Code (2009 edition), as amended by City Code;

City of Portland Fire Department Rules and Regulations;

NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and

NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine