

# City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 1359 Washington Ave		Owner: Orr, Michael S.		Phone: 797-9030		Permit No: 981342	
Owner Address:		Lessee/Buyer's Name: Portland House of Pizza		Phone:		Business Name:	
Contractor Name: John A. DiSanto & Sons, Inc.		Address: Portland, ME		Phone: 772-3611		<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>  <b>DEC - 2 1998</b>  <b>CITY OF PORTLAND</b> </div>	
Past Use: Restaurant		Proposed Use: Same		<b>COST OF WORK:</b> \$ 84,000.00 <b>PERMIT FEE:</b> \$ 440.00		<b>INSPECTION:</b> Use Group: A3 Type: 513 Signature: [Signature]	
Proposed Project Description:  Renovate existing brick building  Prior Site Plan & Fnd Permit Pulled - This permit continues work from foundation up		<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied Signature: [Signature]		<b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		<b>Zone:</b> _____ <b>CBL:</b> 401-A-006 <b>Zoning Approval:</b> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
		Permit Taken By: MG		Date Applied For: 25 November 1998		<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	
						<b>Historic Preservation</b> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

Call J. DiSanto for Pick-Up

See permit #98-1287 for foundation  
98-1104 for Signage

## CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

30 November 1998

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT



# COMMENTS

12/8/98 - Did Pre Con w/ Rocco - (Foundation done under separate permit - already in) discussed improvements of Permit - Rocco acknowledged full understanding - will call for Close in R. See Permit #98-1287 for Foundation.

1-8-99 - Rough In ok - ok to Close -

2/17/99 - Final w/ Lt Thompson - ok except for Cooking Equip Exhausts (2) - they don't meet BOCA 93 Mech Code Sect 507 or NFPA 96 - Letter Rec'd from Air-Temp (attached in file) Re: Remediation on ducts by 3/3/99 ok per M. Nugent -

Temp C of C. <sup>Exhaust</sup> 6/15/99

Pizza Restaurant w/ prep

## Conditions

1 - Cooking Equipment Exhaust ducts to be Code Compliant by 3/3/99 + any DRC Requirements

6/24/99 - Ducts & DRC Requirements met - Perm C of C ok

## Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

Issued to Michael S. Orr

LOCATION 1359 Washington Ave. CBL# 401-A-006

Date of Issue June 29, 1999

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 981342, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Restaurant  
Use Group A-3 Type 5 B  
BOCA 1996

Limiting Conditions:

This certificate supersedes  
certificate issued 2-18-99

Approved:

6/29/99 Tammy Munson  
(Date) Inspector

  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

Issued to Michael S. Orr

LOCATION 1359 Washington Ave 401-A 006

Date of Issue 18 February 1999

**This is to certify** that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 981342, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire

APPROVED OCCUPANCY

Restaurant "Portland House of Pizza"  
Use Group A3/Type 5B  
BOCA 1996

Limiting Conditions: TEMPORARY/EXPIRES 15 Jun 99

Due to the time of year final landscaping work could not be completed. Minor bituminous curb installation, final pavement surface, minor drainage ditch construction and loaming and seeding.

This certificate supersedes  
certificate issued

Approved:

(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION *1359 Washington 401-A-6*

Issued to *Michael S. Orr*

Date of Issue *6/29/99*

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. *981342*, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

*Entire*

APPROVED OCCUPANCY

*Restaurant  
Use group A3 Type 5B  
Boca 1996*

Limiting Conditions:

This certificate supersedes  
certificate issued *2/18/99*

Approved:

*T Munson*

(Date)

Inspector

*Please type ASAP*  
Inspector of Buildings

## MEMORANDUM

**TO:** Code Enforcement  
Kandi Talbot, Planner

**FROM:** Jim Wendel, PE, Development Review Coordinator  
Eric Barnes, DeLuca-Hoffman Associates, Inc.

**DATE:** June 2, 1999

**RE:** Certificate of Occupancy  
Portland House of Pizza (1353 Washington Avenue)

---

On May 28, 1999 the site was reviewed for compliance with the conditions of approval dated October 1998. My comment is:

1. No comment. The site appears to be in conformance with the approved site plan.

It is my opinion that a permanent certificate of occupancy could be issued, assuming Code Enforcement has no outstanding issues.



**CITY OF PORTLAND**  
**Planning and Urban Development Department**

**MEMORANDUM**

**TO:** Code Enforcement

**FROM:** Jim Wendel, Development Review Coordinator

**DATE:** February 18, 1999

**SUBJECT:** Certificate of Occupancy  
Portland House of Pizza

On February 18, 1999 a site visit was made to review the site plan conformance and completion of the site work in response to a request for a certificate of occupancy. Our comments are as follows:

1. Due to the time of year final landscape work could not be completed; i.e. minor bituminous curb installation, final pavement surface, minor drainage ditch construction and loaming and seeding. The remaining site work must be completed by June 15, 1999.

It is my opinion that a **temporary Certificate of Occupancy could be issued** assuming Code Enforcement has no outstanding issues.

**AIRTEMP INC.**  
**MECHANICAL CONTRACTORS**  
**11 WALLACE AVE.**  
**S. PORTLAND ME 04106**  
**207-774-2300**  
**207-871-1345 FAX**

**MEMORANDUM**

**TO: Portland Fire Department**

**February 17, 1999**

**ATTN: Kevin Carroll**  
**FROM: Dean H. Grant**  
**RE: Portland House of Pizza - Washington Ave.**

**Dear Sir:**

Per our phone conversation of today. The exhaust duct will be modified to meet NFPA 96 requirements. The exhaust fans shall be extended to 40" to top of upblast rim above the roof to maintain 18" of clearance from combustibles.

Thank you for bringing this compliance issue to our attention. The issues will be rectified with in two weeks.

Should you have any questions please give me a call at 774-2300.

Thank you,

*Dean H. Grant*  
Dean H. Grant

*Talked w/ L. Thompson  
NFPA 96 OK*

*#308.0  
40" Above Roof Surface 175 06.7.1*

*Outstanding  
D.R.C. off to  
Spec with  
Plumber*



# BUILDING PERMIT REPORT

DATE: 30 Nov. 98 ADDRESS: 1359 Washington Ave CBL 401-A-006  
REASON FOR PERMIT: Renovations / Additions  
BUILDING OWNER: Michael S. Orr  
CONTRACTOR: John B. DiSanto & Sons, Inc.  
PERMIT APPLICANT: 1  
USE GROUP A-3 BOCA 1996 CONSTRUCTION TYPE 3A

## CONDITION(S) OF APPROVAL

This Permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: \*1, \*2, \*2.6, \*6, \*17, \*18, \*19, \*20, \*24, \*26, \*27, \*28, \*29, \*30, \*31

- ☒ 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- ☒ 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- 2.5 Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
- ☒ 2.6 Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
3. Precaution must be taken to protect concrete from freezing. Section 1908.0
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- ☒ 6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
9. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread, 7" maximum rise. (Section 1014.0)
11. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8") 1014.4
2. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special

knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. ( Section 1018.6 )

13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1

14. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0

15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1

16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):

- In the immediate vicinity of bedrooms
- In all bedrooms
- In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2

\*17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. Section 921.0

\*18. The Fire Alarm System shall be maintained to NFPA #72 Standard.

\*19. The Sprinkler System shall maintained to NFPA #13 Standard.

\*20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)

21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".

22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.

23. Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)

\*24. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.

\*25. All requirements must be met before a final Certificate of Occupancy is issued.

\*26. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).

\*27. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). ( Chapter M-16 )

\*28. Please read and implement the attached Land Use-Zoning report requirements.


\*29. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.3. of the City's building code.

\*30. Glass and glazing shall meet the requirements of Chapter 24 of the building code.

\*31. All food service equipment shall be <sup>installed</sup> in accordance with The  
STATE OF MAINE & City of PORTLAND rules & regulations for Food Service.

\*32.

33.

 Samuel Moffatt, Building Inspector

cc: Lt. McDougall, PFD

Marge Schmuckal, Zoning Administrator

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE  
PERMIT IS ISSUED**

**Building or Use Permit Pre-Application  
Attached Single Family Dwellings/Two-Family Dwelling  
Multi-Family or Commercial Structures and Additions Thereto**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

**NOTE\*\*If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction (include Portion of Building): 1359 Washington Avenue, Portland, Maine			
Total Square Footage of Proposed Structure	2717.88 sf	Square Footage of Lot	23,468.42 sf
Tax Assessor's Chart, Block & Lot Number	Owner: Michael S. Orr	Telephone#: 797-9030	
Chart# 401 Block# A Lot# 6			
Owner's Address: 31 Jameco Mill Road Scarborough, Maine	Lessee/Buyer's Name (If Applicable)	Cost Of Work:	Fee \$84,000.00 \$440
Proposed Project Description: (Please be as specific as possible) Renovate existing Brick Building to the Portland House of Pizza. Change of use from Child preschool to restaurant.			
Contractor's Name, Address & Telephone John B. DiSanto & Sons, Inc. Portland, Maine 772-3611			Rec'd By <i>[Signature]</i>
Current Use: Preschool Daycare	Proposed Use: Restaurant		

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

**4) Building Plans**

**Unless exempted by State Law, construction documents must be designed by a registered design professional**

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.


**Certification**

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>Michael S. Orr</i>	Date: 11/25/98
---	----------------

Building Permit Fee: \$25.00 for the 1st \$1000. cost plus \$5.00 per \$1,000.00 construction cost thereafter.

Additional Site review and related fees are attached on a separate addendum



REVIEWED FOR

BARRIER FREE

COMPLIANCE

**STATE OF MAINE**  
**DEPARTMENT OF PUBLIC SAFETY**  
**LICENSING AND INSPECTIONS UNIT**  
**AUGUSTA**  
**CONSTRUCTION PERMIT**



Permit N° 9651

PERMISSION IS HEREBY GIVEN TO:

Location of project:

PROJECT TITLE:

Michael S. Orr  
Portland House of Pizza  
1373 Washington Ave.

1359 Washington Ave.

Portland House of Pizza

OCCUPANCY CLASSIFICATION:

Portland, ME 04101

Portland, ME

Assembly Class "C"

To construct or alter the afore referenced building according to the plans hitherto filed with the Commissioner and now approved. No departure from such plans shall be made without prior approval in writing.

This permit will expire at midnight on May 11, 1999  
This permit is issued under the provisions of Title 25, Chapter 317, Section 2448


Nothing herein shall excuse the holder of this permit for the failure to comply with local ordinances, zoning laws, or other pertinent legal restrictions.

Dated the 12th day of November

A.D. 1998

FEE \$ 150/50

NOT SPRINKLED

  
Commissioner Public Safety