

CITY OF PORTLAND  
FIRE PREVENTION BUREAU  
380 Congress Street, Portland, Maine 04101  
fireprevention@portlandmaine.gov  
(207) 874-8400

**NOTICE OF VIOLATION AND ORDER TO CORRECT**

September 11, 2017

<b>Responsible Party 1:</b> ORR MICHAEL S 4 WILDROSE LN SCARBOROUGH, ME 04074		
<b>Location</b> 1355 WASHINGTON AVE	<b>CBL</b> 401 A006001	<b>Inspection Date</b> 8/16/2017
<b>Inspector</b> Edward Doughty	<b>Inspection Type</b> FP Routine Inspection	<b>Status</b> Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

**You must send this form to the Fire Prevention Bureau no later than 9/30/2017.**

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

<b>Violation</b>	<b>Proposed Date of Completion</b>
<b>NFPA 101- 31.3.2.1.1 BOILER PROTECTION REQUIRED;</b> The areas described in Table 31.3.2.1.1 shall be protected as indicated: Boiler and fuel-fired heater rooms serving more than a single dwelling unit (minimum separation/protection is 1 hour or sprinklers) Must have a Sprinkler Head over the Natural Gas supplied Hot Water Heater located in the Utility Closet	
<b>NFPA 101- 4.5.3.4 MEANS OF EGRESS SHALL BE ILLUMINATED;</b> Lighting: Where artificial illumination is needed in a building or structure, egress facilities shall be included in the lighting design. Exit Sign for the Rear Door needs to be serviced. The Illumination appears to need a luminescent bulb replaced.	
<b>FINAL DATE OF COMPLETED VIOLATION(S)</b>	___/___/___
<b>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</b>	___/___/___

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

### **VIOLATOR CERTIFICATION**

*I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.*

*I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.*

*If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.*

---

Date

---

Responsible Party

---

Date

---

Responsible Party

### **SEEN AND AGREED**

---

Date

---

Fire Prevention Bureau