TYPICAL PAVEMENT JOINT
NOT TO SCALE

BITUMINOUS DRIVEWAY CONSTRUCTION
NOT TO SCALE

PIPE INSULATION DETAIL
NOT TO SCALE

TYP. FOUNDATION DRAIN SECTION
NOT TO SCALE

TRENCH SECTION
NOT TO SCALE

CABLES TO BE ENCASED IN SCHEDULE 40 PVC CONDUIT WHEN RUN BENEATH PAVED AREAS.

TYPICAL UNDERGROUND CABLE INSTALLATION
NOT TO SCALE

STONE DRIP EDGE
NOT TO SCALE

NOTES:

1. PIPE DIAMETERS MAY VARY, SEE TYPICAL PIPE TRENCH DETAIL THIS SHEET.
2. WHERE 30° MINIMUM ANGLE BETWEEN SEWER CONNECTION AT THE SEWER MAIN AND THE VERTICAL CANNOT BE MAINTAINED, PROVIDE A PRECAST SEWER CHIMNEY.
3. IF STAKE IS CUT OFF FLUSH OR SLIGHTLY BELOW GRADE, PROVIDE MIN. OF TWO 16d. GALV. SPIKES DRIVEN INTO TOP OF 2" x 4" TO PROVIDE METAL DETECTABILITY.

HORIZONTAL SANITARY & STORM DRAIN CONNECTION
NOT TO SCALE

SERVICE TAP
(3/4" AND 1" C.C. THREAD)

SERVICE SADDLE
(1-1/2" AND 2" C.C. THREAD)

TYPICAL SERVICE CONNECTION
NOT TO SCALE

STEVE HARDING, PE6633

CITY OF PORTLAND MAINE
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 05/04/15

DESIGNED	CHECKED
SDH	SDH

REV	BY	DATE	STATUS
B	MWE	5-1-15	REVISED PER REVIEW COMMENTS
A	MWE	04-14-15	ISSUED FOR CLIENT REVIEW

THIS PLAN SHALL NOT BE MODIFIED WITHOUT WRITTEN PERMISSION FROM SEBAGO TECHNICS, INC. ANY ALTERATIONS, AUTHORIZED OR OTHERWISE, SHALL BE AT THE USER'S SOLE RISK AND WITHOUT LIABILITY TO SEBAGO TECHNICS, INC.

SEBAGO TECHNICS
WWW.SEBAGOTECHNICS.COM
75 John Roberts Rd. Suite 1A South Portland, ME 04106 Tel. 207-200-2100
250 Goddard Rd. Suite B Lewiston, ME 04240 Tel. 207-782-5635

DETAILS
OF:
LOT 2
419 ALLEN AVENUE
PORTLAND, MAINE
FOR:
ESTES CUSTOM BUILDERS
733 ROOSEVELT TRAIL
WINDHAM, MAINE 04062

PROJECT NO.	SCALE
15098	NONE

SHEET 4 OF 4

15098D.dwg, TAB:D2