389 Congress St. Portland, ME 04101 Phone: (207)874-8700

Fax: (207)874-8716

## facsimile transmittal

Го:	Greg McCormick	From:	Mike Nugent
ax:	871-8695	Date:	April 23, 2002
Phone:	772-2127	Pages:	1
Re:	29 Liberty Way (405ADD022)	CC:	
□ Urge	nt □ For Review □ Please Comme	ent l	☑ Please Reply □ Please Recycle
Notes:	• • • • In order to continue the review of the plan	ns for the	• • • • • • eabove property we need the following :
1)	Perimeter footing dimensions		
2)	What method of sill anchor is being used		
3)	Please provide sizes of LVL's where omitt	ed	
4)	Please Provide product information on BCI	400 floo	or systems
5)	Front Deck Detail		
6)	The omission of a rear deck requires a pla	n to prote	ect the opening of the slider
7)	If there is a window abutting the tub on sh	eet 2 plea	ase provide glazing specs
8)	Egress Window specs		
9)	Interior and exterior Stair and Guard details	<u> </u>	