

•
•
•
•
•
•
•
•

facsimile transmittal

To: Greg McCormick **From:** Mike Nugent
Fax: 871-8695 **Date:** April 30, 2002
Phone: 772-2127 **Pages:** 1
Re: 29 Liberty Was (405AAD022) **CC:**

Urgent For Review Please Comment Please Reply Please Recycle



• • • • • • • • • •

Notes: Thank you for the resubmitted framing plan. There are items on the April 23rd, list that still are either not provided or acceptable:

- 1) Riser detail for cellar stairs
- 2) Guard rail details
- 3) Slider Protection Detail
- 4) Perimeter Footing Dimensions
- 5) Type of sill anchor system

Jay Reynolds has advised that he can not approve this plan until he receives an amended plan showing the no cut buffer and the commitment not to cut the no cut buffer.

