

NOTE: Openings for chimneys shall maintain 2'' minimum clearance between CHIMNEY AND COMBUSTABLE FRAMING MEMBERS. CLEARANCE SHALL BE FIREBLOCKED WITH NON-COMBUSTIBLE MATERIAL AT ALL CEILINGS AND FLOORS.





