

41-45 MAINE AVENUE



First cut #920R - Half cut #920R - Third cut #3203R - Fifth cut #9205R



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, August 28, 1947

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 43 Maine Avenue Use of Building Dwelling No. Stories 1 1/2 ☒ New Building
Name and address of owner of appliance Daniel S. Toppi, 43 Maine Avenue Existing "☐
Installer's name and address James L. McKenna, 218 Park Avenue Telephone 3-0418

General Description of Work

To install steam heating system in place of existing warm air heat

IF HEATER, OR POWER BOILER

Location of appliance or source of heat basement Type of floor beneath appliance concrete
If wood, how protected? Kind of fuel oil
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace 3'
From top of smoke pipe 4' From front of appliance Over 4' From sides or back of appliance Over 3'
Size of chimney flue 8x8 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour

IF OIL BURNER

Name and type of burner Labelled by underwriter's laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner
Location of oil storage Number and capacity of tanks
If two 275-gallon tanks, will three-way valve be provided?
Will all tanks be more than five feet from any flame? How many tanks fire proofed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Kind of fuel Type of floor beneath appliance
If wood, how protected?
Minimum distance to wood or combustible material from top of appliance
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

APPROVED:

OK 8-28-47. JMS

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes


Signature of Installer

James L. McKenna

INSPECTION COPY

Permit No. 47/2159
Location 4.3 maine Ave
Owner Daniel S. Toppi
Date of permit 8/29/47
Approved 10 8-47 Rm

NOTES



W. J. Jackson
43 Main Ave.

Washington Ave.

STATEMENT ACCOMPANYING APPLICATION FOR BUILDING PERMIT

for car garage
at 3 Maine Avenue

Date 8/9/37

1. In whose name in the title of the property now recorded? *Wm. J. Jacobs*
2. Are the boundaries of the property in the vicinity of the proposed work shown clearly on the ground, and how? *Stake mark line*
3. Is the outline of the proposed work now staked out upon the ground? *Yes*. If not, will you notify the Inspection Office when the work is staked out and before any of the work is commenced?
4. What is to be maximum projection or overhang of eaves or drip? *17"*
5. Do you assume full responsibility for the correctness of the location plan or statement of location filed with this application, and does it show the complete outline of the proposed work on the ground, including bay windows, porches, and other projections? *yes*
6. Do you assume full responsibility for the correctness of all statements in the application concerning the sizes, design and use of the proposed building? *yes*
7. Do you understand that in case changes are proposed in the location of the work or in any of the details specified in the application that a revised plan and application must be submitted to this office before the changes are made? *yes*

Wm. J. Jacobs



APPLICATION FOR PERMIT

1212
PERMIT ISSUED

Class of Building or Type of Structure

Portland, Maine, August 9, 1937 AUG 10 1937

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 45 Maine Avenue Ward 9 Within Fire Limits? no Dist. No. _____
Owner's or Lessee's name and address Winthrop J. Jackson, 45 Maine Avenue Telephone no
Contractor's name and address Owner and Mr. Dresser Telephone _____
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building 1 car garage No. families _____
Other buildings on same lot dwelling house
Estimated cost \$ _____ Fee \$ 50

Description of Present Building to be Altered

Material wood No. stories 1 Heat stove Style of roof hip Roofing asphalt
Last use filling station office No. families _____

General Description of New Work

To move building 12' x 16' from 1221 Washington Avenue to above location
To cut in 2' opening in front of building for garage doors
Existing chimney on outside of building will be taken down

THIS PERMIT DOES NOT INCLUDE THE
RIGHT TO MOVE ANY BUILDING THROUGH
THE PUBLIC STREETS OF THE CITY

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? solid earth or rock? earth
Material of foundation mud sills Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering _____
No. of chimneys no Material of chimneys _____ of lining _____
Kind of heat no Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls _____ lengthen floor _____ height? _____

If a Garage

No. cars now accommodated on same lot none, to be accommodated 1
Total number commercial cars to be accommodated none
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION

Signature of owner

Winthrop J. Jackson

CHIEF OF FIRE DEPT.

NOTIFICATION BEFORE LASTING
OR CLOSING IN IS IN
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAD

97523

Ward 9 Permit No. 37/1212

Location 43 Maine Ave

Owner Winstrop & Jordan

Date of permit 8/10/37

Notif. closing-in

In ng-in

Final Notif.

Final Inspn. 10/9/37

Cc upancy issued None


NOTES

8/9/37 - Location of Storm

By Stanes O.K. - A.C.

8/10/37 - Not yet determined

A. J. G.





APPLICATION FOR PERMIT TO BUILD

YOU are responsible with the law. If you are not a resident of Portland, Maine, you must file this application with the City of Portland, Maine, before you can build.

To the INSPECTOR OF BUILDINGS, PORTLAND, MEINE
The undersigned hereby applies for a permit to build, according to the following specifications, the Laws of the State of Maine, and the Building Ordinance of the City of Portland:

Location 43 1st 19-194 Ward 2 Within Fire Limits? no
Owner's name and address? August H. Bess, 753
Contractor's name and address? Carl A. Jordan, 32 Portland Street
Architect's name and address?
Proposed occupancy of building (purpose)? dwelling
No. families? 1 apartments? lodgers?
Size, front? 22, depth? 20 No. stories? 1 1/2, height, average grade to highest point of roof? 14
To be erected on solid or filled land? solid earth or rock?
Material of foundation? concrete Thickness, top? 10 bottom? 12
Material of underpinning? concrete blocks over 4 ft. high? yes thickness? 10
Kind of roof (pitch, hip, etc.)? pitch Kind of roofing? asphalt
Kind of heat? gas pipe Material of chimney? brick, of lining? tile

SIZE OF FRAMING MEMBERS

Corner posts? 4x6 Sills? 6x6 Rafters or roof beams? 2x6 on center? 24
Material and size of columns under girders? 5in 17-in pipe on center? 8 1/2
Ledger board used? no Size? Studs (outside walls and carrying partitions) 2 x 4 16" O. C.
Girders 6" x 8" or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts will be all one piece in cross section.

Floor timbers: 1st floor 2x4, 2nd 2x3 finish 3rd attic, 4th
On centers: 1st floor 16, 2nd 16, 3rd , 4th
Span: 1st floor 11ft, 2nd 11ft, 3rd , 4th

All non-carrying partitions running parallel to and supported by the floor joists will have the floor joists doubled under. IF 1ST OR 2ND CLASS BUILDING then if the vertical area of the partition is 80 sq feet or more and if the area of the joists is 10 ft or more.

External walls } thickness { 1st story , 2nd story
Party walls } 1st story , 2nd story

Material of cornice? How fastened?

IF APARTMENT, TENEMENT OR LODGING HOUSE

Dimensions of lot?
Descriptions of other buildings on lot?
Clear distance to rear lot line? , to one side lot line? , to other side lot line?

IF A PRIVATE GARAGE

No. cars to be accommodated?
Other buildings on same lot?
Distance from nearest present building to proposed garage?
All parts of garage, including eaves, will be at least 2 ft. from all lot lines.
Garage will be at least feet from nearest windows of adjoining property.
Will there be a heating plant within building?
If so, how protected?

MISCELLANEOUS

Will the above construction require the removal or disturbing of any shade tree on the public street? no
Plans filed as part of this application? no No. sheets?
Estimated total cost \$ 4,000. Fee? 1.25

Signature of owner or authorized representative?

9

$\frac{24}{814}$

lot 193-194 Main Ave

Eugene Ross

Aug 12/26

9/15/26

Green tree

9/15/26

3:10



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date December 10, 19 87
Receipt and Permit number 22661

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 43 Main Avenue

OWNER'S NAME: Russell E. Woods Jr.

ADDRESS: same

		FEES
OUTLETS:		
Receptacles	Switches	Plugmold
ft. TOTAL <u>1-30</u>		<u>3.00</u>
FIXTURES: (number of)		
Incandescent <u>X</u>	Flourescent	(not strip) TOTAL <u>1-10</u>
Strip Flourescent	ft.	<u>3.00</u>
SERVICES:		
Overhead <u>X</u>	Underground	Temporary
TOTAL amperes <u>200</u>		<u>3.00</u>
METERS: (number of) <u>1</u>		<u>.50</u>
MOTORS: (number of)		
Fractional		
1 HP or over		
RESIDENTIAL HEATING:		
Oil or Gas (number of units)		
Electric (number of rooms)		
COMMERCIAL OR INDUSTRIAL HEATING:		
Oil or Gas (by a main boiler)		
Oil or Gas (by separate units)		
Electric Under 20 kws	Over 20 kws	
APPLIANCES: (number of)		
Ranges <u>X</u>	Water Heaters	
Cook Tops <u>1</u>	Disposals <u>1</u>	
Wall Ovens <u>1</u>	Dishwashers <u>1</u>	
Dryers	Compactors	
Fans	Others (denote)	
TOTAL <u>4</u>		<u>6.00</u>
MISCELLANEOUS: (number of)		
Branch Panels <u>1</u>		<u>1.00</u>
Transformers		
Air Conditioners Central Unit		
Separate Units (windows)		
Signs 20 sq. ft. and under		
Over 20 sq. ft.		
Swimming Pools Above Ground		
In Ground		
Fire/Burglar Alarms Residential		
Commercial		
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under	over 30 amps	
Circus, Fairs, etc.		
Alterations to wire		
Repairs after fire		
Emergency Lights, battery		
Emergency Generators		
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT		INSTALLATION FEE DUE:
FOR REMOVAL OF A "STOP ORDER" (304-16.b)		DOUBLE FEE DUE:
		TOTAL AMOUNT DUE:
		<u>16.50</u>

INSPECTION:

Will be ready on 12/11/87 a.m., 19 87; or Will Call

CONTRACTOR'S NAME: Place Electric

ADDRESS:

TEL:

MASTER LICENSE NO.: 10626

LIMITED LICENSE NO.:

SIGNATURE OF CONTRACTOR:

Russell E. Woods Jr.

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

ELECTRICAL INSTALLATIONS—

Permit Number 4-100001

Location 42 Middle Lane

Hutchins Cap E, no

Date of Permit 12/16/87

Final Inspection 677

By Inspector - W. H. Keel

Permit Application Register Page No. 77

INSPECTIONS:

Service

Service called in

Closing-in

PROGRESS INSPECTIONS:

DATE:

REMARKS:

10/30/89

REMARKS: No bail for funeral

PERMIT ISSUED
OCT 8 1987
PORTLAND, MAINE
7-1987 CITY OF PORTLAND

APPLICATION FOR PERMIT

B.O.C.A. USE GROUP
B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION

To the CHIEF OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE
The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment, or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:
LOCATION 43 Maine Avenue
1 Owner's name and address Russell E. Woods, same 04103
2 Lessee's name and address
3 Contractor's name and address Thomas Kane Assoc.
71 Cheatey Avenue, 04103
Proposed use of building single family
Material No. stories
Other buildings on same lot
Estimated contractual cost \$ 27,500
FIELD INSPECTOR-Mr. @ 775-5451

to construct a 12' x 12' addition with a 10' deck attached to existing dwelling as per plans
Stamp of Special Conditions
Apparel Fees \$
Base Fee
Late Fee
TOTAL \$ 160.00

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

DETAILS OF NEW WORK


Is any plumbing involved in this work?
Is connection to be made to public sewer?
Has septic tank notice been sent?
Height average grade to top of plate
Size, front
Material of foundation
Kind of roof
No. of chimneys
Framing Lumber-Kind
Size Girder
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters:
On centers:
Maximum span:
If one story building with masonry walls, thickness of walls?
1st floor
2nd
3rd
If a GARAGE
No. cars now accommodated on same lot, to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?
APPROVALS BY:
BUILDING INSPECTION-PLAN EXAMINER
ZONING
BUILDING CODE
Fire Dept.
Health Dept.
Others:

Will work require disturbing of any tree on a public street?
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant
Type Name of above
Phone #
Other
and Address

PERMIT # 9429		PORTLAND BUILDING PERMIT APPLICATION DATE 8/4/87	
1. GENERAL INFORMATION			
Owner's name		43 Marine Avenue	
Address		Riverside, E. Woods, Tr.	
Tel.		same 04133	
2. Lessee's name			
Address			
Tel.			
3. Contractor's name		Marte Pools	
Address		199 U.S. Route 1 Scarborough, 04074	
Tel.		863-5558	
4. Is this a legally recorded lot? Yes ☐ No ☐			
II. DESCRIPTION OF WORK:			
to construct 18' x 33' 4" above ground pool			
III. BUILDING DIMENSIONS:			
Street frontage		length	
Side setbacks: front		width	
Side setbacks: back		square footage	
Zoning board approval: no ☐ yes ☐ date		height	
Planning board approval: no ☐ yes ☐ date		# stories	
IV. REVIEW REQUIRED:			
site plan		variance	
subdivision		other	
shore		floodplain mgmt	
enclosed		Number of off-street parking spaces:	
outdoors			
VI. FEES:			
base fee		other fees	
subdivision fee		late fee	
site plan review fee		TOTAL \$50.00	
VII. DETAILS OF WORK			
1. WATER SUPPLY: ☐ public ☐ private		2. SEWER: ☐ public ☐ private	
3. HEAT: type fuel		4. FOUNDATION: type thickness footing	
5. ROOF: type pitch load		6. PLUMBING: SPRINKLER SYSTEM? Yes ☐ No ☐	
10. If 1-story building w/masonry walls: height wall thickness		11. BEDROOM WINDOWS: height sill height width egress window? Yes ☐ No ☐	
9. FRAMING: floor joists ceiling joists studs		size rafters wall studs	
8. CHIMNEY: # flues material # fireplaces		max. on center	
7. ELECTRICAL: service entrance size # smoke detectors			
8. CHIMNEY: # flues material # fireplaces			
VIII. OFFICE USE:			
TAX MAP #		LOT #	
VALUE/STRUCTURE		PERMIT EXPIRATION	
CODE		If other, explain	
X. PROPOSED USE: 437 above ground pool		XI. PAST USE:	
XII. OWNERSHIP: PUBLIC PRIVATE		XIII. EST. CONSTRUCTION COST: 4,300	
XIV. GR. SQ. FT. OF LOT		BUILDING	
COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE			
XV. RESIDENTIAL BUILDINGS ONLY:		BEDROOMS	
# NEW DWELLING UNITS WITH:		1. BDRM. 2. BDRMS 3. BDRMS	
# EXISTING DWELLING UNITS WITH:			
XVI. # RESIDENTIAL UNITS:		# EXISTING DWELLINGS	
TOTAL RESIDENTIAL UNITS		MISCELLANEOUS	
Will work require disturbing of any tree on a public street?			
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?			
NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanical.			
APPROVALS BY:		DATE	
BUILDING INSPECTION - PLAN EXAMINER			
ZONING:			
C.E.O.			
FIRE DEPT.			
District No.			
XVII. SIGNATURE OF APPLICANT		TYPE NAME OF ABOVE	
137874		1 2 3 4	
White - GPCOG Green - Applicant Yellow - Assessor Pink - Office File Gold - Field Inspector			

PERMIT ISSUED
AUG 5 1987
CITY OF PORTLAND



PERMIT # 904 PORTLAND BUILDING PERMIT APPLICATION DATE 8/10/87 PERMIT ISSUED

I. GENERAL INFORMATION
 Location/address of construction 43 Paine Avenue
 1. Owner's name Russell E. Woods Jr. Tel. 797-8724
 Address same 04103
 2. Lessee's name _____ Tel. _____
 Address _____
 3. Contractor's name Maine Gas Tel. _____
 Address Wintham
 4. Is this a legally recorded lot? yes _____ no _____

AUG 10 1987

City Of Portland

II. DESCRIPTION OF WORK:

to place tank above ground - 250 gals.

send permit to #1

III. BUILDING DIMENSIONS: length _____ width _____ square footage _____ height _____ #stories _____

IV. ZONE _____ Street frontage _____ Zoning board approval: no ☐ yes ☐ date _____
 Setbacks: front _____ back _____ side _____ side _____ Planning board approval: no ☐ yes ☐ date _____

V. REVIEW REQUIRED: variance _____ other _____ Number of off-street parking spaces: _____
 site plan _____ subdivision _____ shore _____ floodplain mgmt _____ enclosed _____ outdoor _____

VI. FEES:
 base fee _____ other fees _____
 subdivision fee _____ late fee _____
 site plan review fee _____ TOTAL \$25.00

VII. DETAILS OF WORK

1. WATER SUPPLY: ☐ public ☐ private	7. ELECTRICAL: service entrance size _____ # smoke detectors _____	8. CHIMNEY: # flues _____ material _____ # fireplaces _____
2. SEWER: ☐ public ☐ private, type _____	9. FRAMING: floor joists _____ size _____ max. on center _____ ceiling joists _____ rafters _____ studs _____ wall studs _____	
3. HEAT: type _____ fuel _____	10. If 1-story building w/masonry walls: wall thickness _____ height _____	11. BEDROOM WINDOWS: height _____ width _____ sill height _____ egress window? yes ☐ no ☐
4. FOUNDATION: type _____ thickness _____ footing _____		
5. ROOF: type _____ pitch _____ covering _____ load _____		
6. PLUMBING: SPRINKLER SYSTEM? yes ☐ no ☐		

VIII. OFFICE USE: TAX MAP # _____ LOT # _____ VALUE/STRUCTURE _____ PERMIT EXPIRATION _____	IX. NEW OR PHASED SUBDIVISION REFERENCE: Name _____ Lot _____ Block _____
---	--

CODE: _____ If other, explain _____ Seasonal Condominium Apartment

X. PROPOSED USE: 101 - single family 437 - tank

XI. PAST USE: _____

XII. OWNERSHIP: PUBLIC ☒ PRIVATE ☐

XIII. EST. CONSTRUCTION COST: _____ XIV. GR. SQ. FT. OF LOT BUILDING _____

COMPLETE XV AND XVI ONLY IF THE NUMBER OF UNITS WILL CHANGE

XV. RESIDENTIAL BUILDINGS ONLY: # NEW DWELLING UNITS WITH: 1 BDRM _____ 2 BDRMS _____ 3 BDRMS _____ # EXISTING DWELLING UNITS WITH: _____	XVI. # RESIDENTIAL UNITS: # NEW DWELLINGS _____ # EXISTING DWELLINGS _____ TOTAL RESIDENTIAL UNITS _____
---	---

APPROVALS BY: _____ DATE _____ BUILDING INSPECTION - PLAN EXAMINER _____ ZONING _____ C.E.O. _____ FIRE DEPT. _____	MISCELLANEOUS: Will work require disturbing of any tree on a public street? _____ Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? _____
---	---

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical, and mechanicals.

District No. _____	XVII. SIGNATURE OF APPLICANT: <u>Russell E. Woods Jr.</u> PHONE # _____ TYPE NAME OF ABOVE: <u>Russell E. Woods Jr.</u> 1 2 3 4
--------------------	--

White - GPCOG Green - Applicant Yellow - Assessor Pink - Office File Gold - Field Inspector

City of Portland
Parks/Public Works
55 Portland Street
Portland, Maine 04101

FOR SUBMETER

FOR SEWER USER CHARGE ADJUSTMENTS

The undersigned hereby requests permission to install additional water meter(s) in accordance with Section 322.60 of the "Municipal Code of the City of Portland, Maine"

It is understood that all expenses related to the purchase, installation and maintenance of the meter(s) is to be borne by the applicant.

TO BE COMPLETED BY APPLICANTS

- ☒ Address where sub-meter is requested 43 Maine Ave.
- ☒ Property owner's name Russell E. Woods Jr.
- ☒ Tax Map Reference (On Real Estate Tax Bill) 40838 408-B-859
(Extension 160)
- ☒ Property owner's address Same
- ☒ Person to be contacted to schedule inspections Russell Woods 7978724
(Name and Telephone Number)
- ☒ Portland Water District Account No. (On bill) D12-2205.3
(Fwd 774-5961)
- ☒ Billing Name & Address (On bill) Same

Location and size existing Portland Water District Service Meter 5/8" main meter
in front-right corner of basement below movable bookcase.

Proposed location and size of sub-meter 5/8" sub-meter to be located
overhead, in-line, in the basement to the rear left.

Will a remote reading register be utilized? NO ☒ YES (If yes, state location At
front-left corner of house, driveway side.

Description of proposed changes in plumbing required for sub-metering: ① cut & "sweat-
in" the sub-meter in the line serving the side
yard. ② A #90 Watts back-flow preventer may also
be placed in the same line, if the 84 hose bibb vacuum
the volume of water to be submetered can be shown not to enter the sewerage system by virtue
of its use for: Pool (Swimming)
breaker is not used.

I certify the above information is true and correct:

☒ Russell E. Woods Jr.
Signature

☒ Aug. 6, 87
Date

RECEIVED


Revised 12-30-85

AUG 06 1987

DEPARTMENT OF PUBLIC WORKS

shall pass through meter to non-serviced equipment in
proposed future. Show water flow through meter to non-serviced equipment in
location use additional sheet of paper if necessary.

43 Maine Avenue



TO BE COMPLETED BY PUBLIC WORKS

Pre-installation inspection by Frank Brancely
on August 6, 1987

Automatic reading system requested

☒ YES

☐ NO

(No. 9D, e.g.)

(B) ☒ A BA Watts Hose Bibb Back Flow Preventer or equal shall be
installed on the outside hose bibb, or (in line).

Application

☒ Approved

☐ Denied

Comments 18 ga., two strand bell or thermostat wire
will be required for the remote reader.

TO BE COMPLETED BY THE PLUMBING INSPECTOR

An inspection of the completed installation of the sub-metering system approved
on this application was conducted on 3/8/88 by Ernold R. Goodwin,
Chief Plumbing Inspector of the City of Portland.

☒ The sub-metering system was installed as approved

☒ No cross connections were found

The installation is

☒ approved

☐ dis-approved

E.R. Goodwin

TO BE COMPLETED BY THE WATER DISTRICT

Date submeter sold 8/7/87
Submeter account number D-12-22053
Submeter make and number 5/BR #30533420
Submeter installation readings 427
Submeter installed into computer 3/9/88
Submeter account entered into meter book 3/9/88
Special instructions