
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager WOODS JO-ANN E &		Inspector Suzanne Hunt	Inspection Date 8/4/2010
Location 43 MAINE AVE	CBL 408 B008001	Status Re-Inspect 30 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.(d)	Exterior			Deck	
Violation: Stairways, stairwells, stairs and porches.					
Notes: The exterior deck must be repaired or demolished. Permit required.					

Comments: drive by JGR and SMH the exterior 1 story deck left side is falling off the house