



www.energyservicesofme.com

Energy Services LLC
38 Herford Ave
South Portland
Maine 04102

March 23 2010

Planning & Urban Development Dept.
Inspection Services Division
389 Congress Street Portland Maine

Attention: Nick Adams,

Nick per our conversation about space heater at 1223 Washington Ave. Charlie Shepard cleaned heater and did inspection with my presents at this location. We fired unit and tested to make sure vent and chamber was not cracked or separated. We did find that observation port was opened and unit can not be run with this condition. We installed replacement nuts and re-fired unit. Heater was operational at this time. Heater is scheduled to be replaced in this coming summer season. My license number is PNT 246. Charlie's HPR8276.

Regards,

Butch Beardsley