

ELECTRICAL PERMIT

City of Portland, Me.



6/28/96 pm

To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical code and the following specification:

Date 09 May 1996
 Permit # 4234

LOCATION: 64 Felicia Ln (L #13)

OWNER Jandie Development ADDRESS _____

11-4-691

							TOTAL EACH FEE			
OUTLETS										
		Receptacles		Switches		Smoke Detector	60	.20	12.00	
FIXTURES		(number of)								
		incandescent		fluorescent			12	.20	2.40	
		fluorescent strip						.20		
SERVICES										
		Overhead				TTL AMPSTO	800		15.00	
		Underground					800	100	15.00	
TEMPORARY SERV.										
		Overhead				AMPS OVER	800		25.00	
		Underground					800		25.00	
METERS		(number of)					1	1.00	1.00	
MOTORS		(number of)						2.00		
RESID/COM		Electric units						1.00		
HEATING		oil/gas units						5.00		
APPLIANCES		Ranges	1	Cook Tops		Wall Ovens		2.00		
		Water heaters		Fans	1	Dryers	1	2.00		
Disposals	1	Dishwasher	1	Compactors		Others (denote)		2.00	10.00	
MISC. (number of)		Air Cond/win						3.00		
		Air Cond/cent						10.00		
		Signs						5.00		
		Pools						10.00		
		Alarms/res						5.00		
		Alarms/com						15.00		
		Heavy Duty						2.00		
		Outlets								
		Circus/Carnv						25.00		
		Alterations						5.00		
		Fire Repairs						15.00		
		E Lights						1.00		
		E Generators						20.00		
		Panels						4.00		
TRANSFORMER		0-25 Kva						5.00		
		25-200 Kva						8.00		
		Over 200 Kva						10.00		
							TOTAL AMOUNT DUE			
							MINIMUM FEE/COMMERCIAL 35.00		25.00	40.40
							MINIMUM FEE		25.00	40.40

INSPECTION: Will be ready Service Ready or will call _____

CONTRACTORS NAME Michael Floridino

ADDRESS 35 Lawrence Ave

TELEPHONE 772-3136

MASTER LICENSE No. 4234

LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

Mike Floridino

ELECTRICAL INSTALLATIONS—

INSPECTION: Service _____ by _____
 Service called in _____
 Closing-in _____ by _____

Permit Number 9234
 Location 64 Electric Lane
 Owner Jandice Condr.
 Date of Permit 5/9/96
 Final Inspection 12/23/96
 By Inspector [Signature]

PROGRESS INSPECTIONS: 6/28/96 (Rough-in)
12/23/96 (Final)
 _____ | _____ | _____
 _____ | _____ | _____
 _____ | _____ | _____
 _____ | _____ | _____

DATE:	REMARKS:
5-9-96	Temp service /w GFI / grounding rod not 8' in ground yet Some called for Meter & etc. to set ok!
12/23/96	Violations, connections must be made @
	- Boiten wiring
	- (3) way cellan lights
	- strapping on ground wire
	- outside outlet (not in)
	- wire boxes used on cellan lights
	- must use round boxes
	- front door button ?