



... Fire Protection by Computer Design

FPSS
278 HARRIS ROAD
MINOT MAINE 04258
207-393-7422

Job Name : 60 HUNTINGTON AVE. PORTLAND
Building : 60 HUNTINGTON AVE. PORTLAND, ME
Location : 2ND FLOOR BEDROOMS
System : 1
Contract :
Data File : 60 HUNTINGTON AVE PORTLAND w-meter.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 60 HUNTINGTON AVE. Date - 12-19-13
 Location - 2ND FLOOR BEDROOMS
 Building - 60 HUNTINGTON AVE. PORTLAND, ME System No. - 1
 Contractor - RICHARD MARTIN PLUMBING & HEATING Contract No. -
 Calculated By - TIM FORTIN Drawing No. - SP-1
 Construction: (X) Combustible () Non-Combustible Ceiling Height 8'
 OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date
 E
 M Listed Flow at Start Point - 14 Gpm System Type
 Listed Pres. at Start Point - 10.2 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 14 x 14 () Deluge () PreAction
 E Domestic Flow Added - 5 Gpm Sprinkler or Nozzle
 S Additional Flow Added - 0 Gpm Make RELIABLE Model F1RES44
 I Elevation at Highest Outlet - 27 Feet Size 1/2" K-Factor 4.4
 G Note: Temperature Rating 155
 N

Calculation Gpm Required 33 Psi Required 73 At Test
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 7-18-90/ Rated Cap. Cap.
 T Time of Test - 2-21-12 @ Psi Elev.
 E Static (Psi) - 68 Elev.
 R Residual (Psi) - 34 Other Well
 Flow (Gpm) - 750 Proof Flow Gpm
 S Elevation - -2

P Location: TEST HYDRANT IS 550' WEST OF SITE ON HUNTINGTON AVE.
 P THE HYDRANT WAS TESTED IN 1990 AND AGAIN IN 2012 WITH A GREATER STATIC PRESS
 L Source of Information: PORTLAND WATER DISTRICT
 Y WE ARE USING THE NEW STATIC PRESSURE WITH THE OLD RESIDUAL AND FLOW.


Water Supply Curve (C)

FPSS
60 HUNTINGTON AVE. PORTLAND

Page 2
Date 12-22-13

City Water Supply:
C1 - Static Pressure : 91
C2 - Residual Pressure: 34
C2 - Residual Flow : 750

Demand:
D1 - Elevation : 12.560
D2 - System Flow : 33.1049
D2 - System Pressure : 72.557
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 33.1049
Safety Margin : 18.265



Fittings Used Summary

FPSS
60 HUNTINGTON AVE. PORTLAND

Page 3
Date 12-22-13

Fitting Legend		½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	
Abbrev. Name																					
24																					
Bt	Ball Vic 728 Thrd	0	0	0.5	1	1.7	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	0
61																					
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	
13																					
N *	CPVC 90'EII Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	
121																					
Y	Mechanical Tee	2	4	5	6	8	10.5	12.5	15.5	0	22	0	0	0	0	0	0	0	0	0	0
Zik	Wilkins 950XL	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

FPSS
60 HUNTINGTON AVE. PORTLAND

Page 4
Date 12-22-13

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
1	27.0	4.4	10.2	na	14.05	0.05	196	10.2
2	27.0	4.4	10.2	na	14.05	0.05	196	10.2
3	27.0		10.39	na				
4	18.0		16.33	na				
5	18.0		19.9	na				
6	9.0		25.84	na				
TOR	9.0		33.5	na				
BOR	2.0		43.26	na	5.0			
H1	0.0		71.68	na				
TEST	-2.0		72.56	na				

The maximum velocity is 16.29 and it occurs in the pipe between nodes BOR and H1

Final Calculations - Hazen-Williams

FPSS
60 HUNTINGTON AVE. PORTLAND

Page 5
Date 12-22-13

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
1 to 3	14.05 14.05	1.101 150.0 0.0354	1O 5.0 0.0 0.0	0.250 5.000 5.250	10.200 0.0 0.186		K Factor = 4.40 Vel = 4.73
	0.0 14.05					10.386	K Factor = 4.36
2 to 3	14.05 14.05	1.101 150.0 0.0354	1O 5.0 0.0 0.0	0.250 5.000 5.250	10.200 0.0 0.186		K Factor = 4.40 Vel = 4.73
3 to 4	14.05 28.1	1.101 150.0 0.1277	1N 7.0 0.0 0.0	9.000 7.000 16.000	10.386 3.898 2.043		Vel = 9.47
4 to 5	0.0 28.1	1.101 150.0 0.1277	2O 10.0 0.0 0.0	18.000 10.000 28.000	16.327 0.0 3.575		Vel = 9.47
5 to 6	0.0 28.1	1.101 150.0 0.1276	1N 7.0 0.0 0.0	9.000 7.000 16.000	19.902 3.898 2.042		Vel = 9.47
6 to TOR	0.0 28.1	1.101 150.0 0.1277	2N 14.0 1O 5.0 0.0	41.000 19.000 60.000	25.842 0.0 7.661		Vel = 9.47
TOR to BOR	0.0 28.1	1.101 150.0 0.1278	1Zik 0.0 0.0 0.0	5.000 0.0 5.000	33.503 9.117 0.639		* Fixed loss = 6.086 Vel = 9.47
BOR to H1	5.00 33.1	0.911 150.0 0.4348	1Y 3.801 1Bt 0.38 0.0	50.000 4.181 54.181	43.259 4.866 23.559		Qa = 5.00 * Fixed loss = 4 Vel = 16.29
H1 to TEST	0.0 33.1	8.27 140.0 0.0	1G 6.326 1T 55.354 1E 28.468	550.000 90.148 640.148	71.684 0.866 0.007		Vel = 0.20
	0.0 33.10					72.557	K Factor = 3.89