

Inspection Services  
Michael J. Nugent  
Manager

Department of Urban Development  
Joseph E. Gray, Jr.  
Director



## CITY OF PORTLAND

August 6, 1999

Oren Mikulanecz  
3 Demerest st  
Portland ME 04103

CBL: 410-E-033

Dear Sir or Madam:

It was recently noted that your swimming pool was not installed in accordance with Section 421.0 of the 1996 BOCA Code as stipulated in your permit issued August 6, 1999.

The following is a list of violation(s) I recognized in reviewing your pool:

1. No self closing gate

I will be glad to meet with you on site to fully explain these requirements.

Please note the failure to contact this office within 10 days will result in legal action being taken.

Sincerely,

Jon Reed  
Code Enforcement Officer

/sap