lenity
architecture

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 04/11/16

Fire Department Information

February 8, 2016

Contact Information:
Lenity Architecture
Dan Roach, Architect
Ron Jackson, Permit Expeditor
3150 Kettle Ct. SE.
Salem, OR 97301
503-399-1090

Proposed use of Structure (NFPA and IBC Classification):

Square footage:

Main Building: 137,038
Garage 1: 1,302
Garage 2: 1,302
Van Garage: 1,720

Existing and Proposed fire protection of structure: Existing: NA / Proposed: 13

Deferred Plans (separate permit): Suppression system and Detection system

Life Safety Plan (to include)

a. Fire resistance ratings of all means of egress
b. Travel distance from most remote point to exit discharge
c. Location of any required fire extinguishers
d. Location of emergency lighting
e. Location of exit signs
f. NFPA 101 code summary

All of this information is in our plans.

Elevators shall be sized to fit an 80" x 24" stretcher: yes