

## Post & Columns

### Wood Column Design Analysis -

Douglas Fir-Larch, #2 2x4 Height: 9 feet 0 inches

	Fc//	Cf	CM	CD	Ct	Cx	Adjusted
	1300	1.15	1	1	1	1	1495
E	1600000		1	1	1	1	1600000

Allowable Load: 2428 Pounds <  $P_{BR} = 625 \times 1.5 \times 3.5 = 3281\#$

Douglas Fir-Larch, #2 2x6 Height: 9 feet 0 inches

	Fc//	Cf	CM	CD	Ct	Cx	Adjusted
	1300	1.1	1	1	1	1	1430
E	1600000		1	1	1	1	1600000

Allowable Load: 7565 Pounds >  $P_{BR} = 5156\#$

Douglas Fir-Larch, #2 4x4 Height: 9 feet 0 inches

	Fc//	Cf	CM	CD	Ct	Cx	Adjusted
	1300	1.15	1	1	1	1	1495
E	1600000		1	1	1	1	1600000

Allowable Load: 5667 Pounds <  $P_{BR} = 7656\#$

Douglas Fir-Larch, #2 4x6 Height: 9 feet 0 inches

	Fc//	Cf	CM	CD	Ct	Cx	Adjusted
	1300	1.1	1	1	1	1	1430
E	1600000		1	1	1	1	1600000

Allowable Load: 8662 Pounds <  $P_{BR} = 12031\#$

Douglas Fir-Larch, #2 6x6 Height: 9 feet 0 inches

	Fc//	Cf	CM	CD	Ct	Cx	Adjusted
	1300	1	1	1	1	1	1000
E	1600000		1	1	1	1	1600000

Allowable Load: 23014 Pounds >  $P_{BR} = 18906\#$

DAN GREEN  
ENGINEERING, INC.  
SALEM, OREGON

FILE NO. \_\_\_\_\_ SHEET NO. PH. 3  
DESIGNER \_\_\_\_\_ DATE \_\_\_\_\_  
CLIENT \_\_\_\_\_  
PROJECT \_\_\_\_\_