



OPTIONAL GARBAGE DISPOSAL PLUMBING
ILLINOIS MODELS ONLY - USE DETAIL ABOVE FOR
OPTIONAL GARBAGE DISPOSAL.

PIPE SUPPORT:

VERTICAL PIPING:

SUPPORTS AT 10' O.C. MAX.
OR BETWEEN FLOOR
LEVELS.

HORIZONTAL PIPING:
SUPPORTS AT 4' O.C. MAX.
ENDS OF BRANCHES, AND
AT CHANGES IN ELEVATION
AND/OR DIRECTION.

TRAP ARMS:
SUPPORT LOCATED AS
CLOSE TO TRAP AS
POSSIBLE WHEN TRAP TO
VENT EXCEEDS 3'.

NOTES:

- ALL BELOW FLOOR PLUMBING BY OTHERS. ALL FITTINGS BELOW BOTTOM CAN BE SHIPPED LOOSE.
- ALL BELOW FLOOR PLUMBING ILLUSTRATIONS ARE RECOMMENDATIONS ONLY. ON-SITE CONDITIONS AND/OR RESTRICTIONS MAY REQUIRE SOME MODIFICATIONS.
- OPT. GARBAGE DISPOSAL TO BE LOCATED ON KITCHEN SINK WASTE ASSEMBLY. ALL VENTS THRU ROOF TO BE 3", 12" MIN. ABOVE AND BELOW ROOF PENETRATION.
- ALL P-TRAPS TO BE 1 1/2" UNLESS NOTED.
- HORIZONTAL VENT SLOPE 1/8" PER FOOT
- HORIZONTAL DRAIN SLOPE 1/4" PER FOOT
- DRAIN, WASTE, AND VENT PLUMBING TO BE PVC PLASTIC OR EQUAL, APPROVED FOR DWV APPLICATIONS.
- ANY TRANSITIONS TO MATERIALS, OTHER THAN THE SPECIFIED MATERIAL, MUST INCORPORATE AN APPROVED FITTING FOR CONNECTION.
- ALL TUBS WITH WHIRLPOOL MUST BE PROVIDED WITH ACCESS TO MOTOR. ALL PLUMBING TO MEET OR EXCEED CURRENT ADOPTED PLUMBING CODES.
- IN CONCEALED SPACES WHERE PIPING IS INSTALLED THRU HOLES OR NOTCHES IN STUDS, JOISTS, TRUSSES, OR SIMILAR MEMBERS LESS THAN 1 1/2" FROM NEAREST EDGE OF THE MEMBER, THE PIPE SHALL BE PROTECTED BY SHIELD PLATES. PROTECTIVE SHIELD PLATES SHALL BE A MINIMUM OF 16 GA. STEEL. PLATES SHALL COVER AREA OF THE PIPE WHERE THE MEMBERS ARE NOTCHED OR BORED, AND SHALL EXTEND A MINIMUM OF 2" ABOVE SOLE PLATES AND BELOW TOP PLATES.
- ALL WATER HEATERS AND WATER HEATER PLUMBING TO BE SUPPLIED AND INSTALLED IN BASEMENT BY OTHERS IN ACCORDANCE WITH ALL RECOGNIZED PLUMBING CODES.
- AIR ADMITTANCE VALVES MAY SUBSTITUTE ROOF VENTS AT VARIOUS LOCATIONS PER APPLICABLE STATE AND LOCAL PLUMBING CODES. THE 3" MAIN VENT MUST BE VENTED THRU THE ROOF AND CANNOT BE MECHANICALLY VENTED.

Builder Pennwest Homes	Callout 2634	Revisions Date Number	Scale N.T.S.	Date 03/03/2014	Cust Stock Schlavi Home Builders	Modeling No. HZ106-A1
Title DWV Notes			Drawn by RM	Reference NONE	S/N	Pg DN