Reviewed for Code Compliance
Inspections Division
Approved as Noted
Date: 05/24/16

Distance from Vert BWL 1 to Vert BWL 2 = 34 ft

	Input Panel Lengths Below, ft							
	Exterior Horizontal Braced Wall Lines				Exterior Vertical Braced Wall Lines			
	Horizontal BWL 1		Horizontal BWL 2		Vertical BWL1		Vertical BWL2	
BW Type:	WSP		WSP		WSP		WSP	
	Actual	Effective	Actual	Effective	Actual	Effective	Actual	Effective
	12.276	12.276	5.448	5.448	13.583	13.583	14.219	14.219
	6.693	6.693	3.901	3	9.25	9.25	4	4
	3.969	3	3.901	3	0	0	0	0
	0	0	3.385	2.25	0	0	0	0
	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0
Lp =	21.969 ft		13.698 ft		22.833 ft		18.219 ft	
Lr =	10.092 ft		10.092 ft		12.914 ft		12.914 ft	
Meets Requirements?	OK		OK		OK		OK	
Horizontal Joint Blocking Required ?	NO		YES		YES		YES	

	Interior Vertical Braced Wall Lines, Method GB					
	N/A		N/A		N/A	
BW Type:	GB		GB		GB	
	Actual	Effective	Actual	Effective	Actual	Effective
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
	0	0	0	0	0	0
Lp =	0 ft		0 ft		0 ft	
Lr =	0.000 ft		0.000 ft		0.000 ft	
Meets Requirements?	N/A		N/A		N/A	
Horizontal Joint Blocking?	N/A		N/A		N/A	

Note: All GB BW panels must have GYP on both sides of the wall section. All WSP BW panels must have GYP on the other side of the wall section.

(Table 2)