DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

TPO PROPERTIES LLC

Located at

59 ICE POND DR

PERMIT ID: 2018-00033 **ISSUE DATE:** 02/28/2018

CBL: 414 A019001

has permission to Construct single family ranch style home with attached 2 car garage, front porch and rear deck

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required. A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

Fire Department

/s/ Greg Gilbert

/s/ Greg Gilbert

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning single-family

Building InspectionsUse Group:Type:New single Family Residence13D Sprinkler

ENTIRE

2009 IRC / MUBEC

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Final - DRC Site VISIT Setbacks and Footings Prior to Pouring Foundation/Rebar Foundation/Backfill Close-in Plumbing/Framing Electrical - Residential FP Sprinkler Final - Electric Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

Located at: 59 ICE POND DR

| City of Portland, Maine - Building or Use Permit | | Permit No: | Date Applied For: | CBL: |
|--|-------------------------------|--|------------------------|--|
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87 | 4-8716 | 2018-00033 | 01/09/2018 | 414 A019001 |
| Proposed Use: | Proposed Project Description: | | | |
| Single Family Home | | ct single family ra rch and rear deck | nch style home with | attached 2 car garag |
| Dept: Zoning Status: Approved w/Conditions Re | viewer: | Christina Stacey | Approval Da | ate: 01/23/2018 |
| Note: R-3 zone | | Chilibana Stacey | | Ok to Issue: |
| Extreme NW corner of lot is Flood Zone A, Panel 2 - BFE de (submitted as part of subdivision approval). First floor elevation of house 76.5' and finished basement elev | | | Design Solutions | |
| Conditions: | vation oo. | 5 - nouse is outsic | le of flood zone. | |
| Separate permits shall be required for future decks, sheds, pools, a | and/or gar | ages. | | |
| 2) A copy of the final recorded deed for the property shall be submitt | • | • | | |
| 3) This property shall remain a single family dwelling. Any change o approval. | | - | e permit application | for review and |
| 4) This permit is being approved on the basis of plans and documenta before starting that work. | s submitte | ed. Any deviations | s shall require a sepa | rate approval |
| Dept: Building Inspecti Status: Approved w/Conditions Re Note: | eviewer: | Greg Gilbert | Approval Da | ate: 02/28/2018 Ok to Issue: ✓ |
| Conditions: | | | | |
| This permit is approved based upon information provided by the a approved plans requires separate review and approval prior to work | | or design professio | onal. Any deviation f | rom the final |
| Review and approval by the Authority having Jurisdiction shall no this Code | ot relieve | the applicant of the | e responsibility of co | mpliance with |
| 3) All construction shall comply with City Code Chapter 10. | | | | |
| Separate permits are required for any electrical: plumbing, sprinkl and fuel tanks. Separate plans may need to be submitted for appro | | | | exhaust systems |
| Dept: Fire Status: Approved w/Conditions Re | viewer: | Greg Gilbert | Approval Da | ate: 02/06/2018 |
| Note: | | | | Ok to Issue: |
| Conditions: | | | | |
| 1) Fire extinguishers are required per NFPA 1 (2009 Edition) Table accordance with NFPA 1, 13.6.8. | 13.6.2. TI | ne quantity, size, ty | ype and location shal | l be in |
| 2) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety Co All construction shall comply with 2009 NFPA 1, Fire Code. This review and approval by the AHJ shall not relieve the applicat (section 1.14.4). | - | | ompliance with this C | Code. NFPA 1 |
| City of Portland Code Chapter 10 section 10-3 (L) all residential of parking structures or fuel burning appliances shall be protected in Carbon Monoxide (CO) Detection and Warning Equipment, 2009 Outside each separate sleeping area, in the immediate vicini 2. On each | accordan edition. | ce with NFPA 720 Detectors shall be |), Standard for the In | stallation of |
| | | | | |

- 4) City of Portland Code Chapter 10 section 10-3 (i) all new single-station and or multiple-station smoke alarms shall be nonionization (photoelectric) type. Smoke Alarms shall be installed per NFPA 101 2009 section 9.6.2.10. Detectors are required to be installed in the following locations
 - 1. Inside all sleeping rooms.
 - 2. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas
 - 3. On each level of the dwelling unit, including basements but excluding attics and crawl spaces.

 Dept:
 DRC
 Status:
 Approved w/Conditions
 Reviewer:
 Rob Wiener & Philip
 Approval Date:
 02/28/2018

 Note:
 Ok to Issue:
 Image: Conditional Conditiona Conditional Condition Conditional Condite Con

Conditions:

- 1) The site shall be developed and maintained as depicted in the approved site plan, written submission of the applicant, and these written conditions of approval. The modification of the approved site plan or alteration of a parcel which was the subject of site plan approval shall require the prior approval of a revised site plan by the Planning Authority.
- 2) The Development Review Coordinator (874-8632) must be notified five (5) working days prior to date required for final site inspection. Please make allowances for completion of site plan requirements determined to be incomplete or defective during the inspection. This is essential as all site plan requirements must be completed and approved by the Development Review Coordinator prior to issuance of a Certificate of Occupancy. Please schedule any property closing with these requirements in mind.
- 3) All damage to sidewalk, curb, street, or public utilities shall be repaired to City of Portland standards prior to issuance of a certificate of occupancy.
- 4) A street opening permit(s) may be required for your site. Please contact Public Works at 874-8300, ext. 8822. (Only excavators licensed by the City of Portland are eligible.)
- 5) All Site work (final grading, landscaping, loam and seed) must be completed prior to issuance of a certificate of occupancy.
- 6) The Development Review Coordinator reserves the right to require additional lot grading or other drainage improvements as necessary due to field conditions.
- 7) Erosion and Sedimentation control shall be established and inspected by the Development Review Coordinator prior to soil disturbance, and shall be done in accordance with Best Management Practices, Maine Department of Environmental Protection Technical and Design Standards and Guidelines. All Erosion and Sedimentation control measures must be inspected and maintaned daily.
- 8) The limits of allowable clearing shall be clearly marked with flagging or temporary fencing. Absolutely no clearing is to take place within, or encroach into the "do not disturb/no cut" zone. All conditions listed in the approved subdivision plan, as they relate to this lot shall be followed.
- 9) The applicant shall have a licensed surveyor install, prior to the issuance of any Certificate of Occupancy, permanent mounumentation/pins identifying property corners.
- 10 This site must comply with the Landscape Preservation Standards outlined in the Land Use Ordinance, section 14-526(b)2a, stating that a minimum of 30% of existing trees, ten (10) inches DBH or greater, within the required setback, must be preserved. Trees that are designated to be saved are to be protected during excavation and construction. Tree protection fencing is to be installed around the tree canopy drip line prior to the start of any excavation. Tree protection measures are to be inspected and maintained daily.
- 11 A performance guarantee will be required to cover the cost of site work not completed due to seasonal conditions ie., finish grading, loaming, seeding, mulching, installation of street trees, etc. The performance guarantee must be reviewed, approved, and accepted by the Planning Authority prior to the release of a Temporary Certificate of Occupancy.
- 12 Two (2) City of Portland approved species and size trees must be planted on your street frontage prior to issuance of a Certificate of Occupancy.