

... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
84 HACKETT MILLS ROAD
P.O. BOX 156
POLAND, ME 04274
207-998-2551

Job Name : Gervais Home 2nd floor calc
Drawing :
Location :
Remote Area :
Contract :
Data File : 2ND FLOOR PEND CALC.WXF


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Gervais Home 2nd floor calc

Page 1
Date 3/14/17

City Water Supply:
C1 - Static Pressure : 74
C2 - Residual Pressure: 20
C2 - Residual Flow : 750

Demand:
D1 - Elevation : 10.611
D2 - System Flow : 28.462
D2 - System Pressure : 57.133
Hose (Demand) : _____
D3 - System Demand : 28.462
Safety Margin : 16.740



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Gervais Home 2nd floor calc

Page 2
Date 3/14/17

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Bvt	Ball Vic 728 Thrd	0	0	0.5	1	1.7	0.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'EII Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zik	Wilkins 950XL	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Gervais Home 2nd floor calc

Page 3
Date 3/14/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	-1.0	4.9	8.2	na	14.03	0.05	256	8.2
DP2	-1.0	4.9	8.2	na	14.03	0.05	256	8.2
20	26.5	K = K @ EQ01	8.03	na	14.03			
21	26.5	K = K @ EQ02	8.42	na	14.43			
22	26.5		9.34	na				
23	16.5		15.63	na				
24	16.0		20.03	na				
25	8.5		25.23	na				
26	8.0		28.33	na				
27	8.0		29.31	na				
TOR	8.0		34.27	na				
FLW	3.0		40.44	na				
BOR	1.0		48.89	na				
WTM	1.0		53.07	na				
H1	1.0		57.56	na				
H2	1.0		57.56	na				
TEST	2.0		57.13	na				

The maximum velocity is 11.74 and it occurs in the pipe between nodes BOR and WTM

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Gervais Home 2nd floor calc

Page 4
Date 3/14/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to EQ01	14.03 14.03	1.101 150.0 0.0353	1N	7.0 0.0 0.0	0.500 7.000 7.500	8.200 -0.433 0.265			K Factor = 4.90 Vel = 4.73	
	0.0 14.03						8.032		K Factor = 4.95	
DP2 to EQ02	14.03 14.03	1.101 150.0 0.0353	1O	5.0 0.0 0.0	0.500 5.000 5.500	8.200 -0.433 0.194			K Factor = 4.90 Vel = 4.73	
	0.0 14.03						7.961		K Factor = 4.97	
20 to 21	14.03 14.03	1.101 150.0 0.0353		0.0 0.0 0.0	11.000 0.0 11.000	8.032 0.0 0.388			K Factor @ node EQ01 Vel = 4.73	
21 to 22	14.43 28.46	1.101 150.0 0.1307	1O	5.0 0.0 0.0	2.000 5.000 7.000	8.420 0.0 0.915			K Factor @ node EQ02 Vel = 9.59	
22 to 23	0.0 28.46	1.101 150.0 0.1307	1O	5.0 0.0 0.0	10.000 5.000 15.000	9.335 4.331 1.960			Vel = 9.59	
23 to 24	0.0 28.46	1.101 150.0 0.1307	1N	7.0 0.0 0.0	25.000 7.000 32.000	15.626 0.217 4.182			Vel = 9.59	
24 to 25	0.0 28.46	1.101 150.0 0.1307	1O	5.0 0.0 0.0	10.000 5.000 15.000	20.025 3.248 1.961			Vel = 9.59	
25 to 26	0.0 28.46	1.101 150.0 0.1307	1N	7.0 0.0 0.0	15.000 7.000 22.000	25.234 0.217 2.875			Vel = 9.59	
26 to 27	0.0 28.46	1.101 150.0 0.1307	1N	7.0 0.0 0.0	0.500 7.000 7.500	28.326 0.0 0.980			Vel = 9.59	
27 to TOR	0.0 28.46	1.101 150.0 0.1307	1N	7.0 0.0 0.0	31.000 7.000 38.000	29.306 0.0 4.966			Vel = 9.59	
TOR to FLW	0.0 28.46	1.049 120.0 0.2500	1Fsp	0.0 0.0 0.0	4.000 0.0 4.000	34.272 5.166 1.000			* Fixed loss = 3 Vel = 10.57	
FLW to BOR	0.0 28.46	1.049 120.0 0.2498	1Zik 1T	0.0 5.0 0.0	1.000 5.000 6.000	40.438 6.952 1.499			* Fixed loss = 6.086 Vel = 10.57	
BOR to WTM	0.0 28.46	0.995 150.0 0.2140	2Bvt	1.168 0.0 0.0	2.000 1.168 3.168	48.889 3.500 0.678			* Fixed loss = 3.5 Vel = 11.74	
WTM to H1	0.0 28.46	1.917 150.0 0.0088	1G 1T	1.047 10.47 0.0	500.000 11.517 511.517	53.067 0.0 4.490			Vel = 3.16	
H1 to H2	0.0 28.46	8.27 120.0 0.0	1T	41.62 0.0 0.0	650.000 41.620 691.620	57.557 0.0 0.007			Vel = 0.17	

Final Calculations - Hazen-Williams

HIGH TECH FIRE PROTECTION
Gervais Home 2nd floor calc

Page 5
Date 3/14/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H2 to TEST	0.0 28.46	6.28 100.0 0.0001	1G 1E	2.537 11.839 0.0	10.000 14.376 24.376	57.564 -0.433 0.002			
	0.0 28.46						Vel = 0.29		
						57.133	K Factor = 3.77		